



Town of Brighton

VERMONT

Town of Brighton, Vermont

Request for Proposal

Heat Pump Installation for Town Garage

Issued: March 12, 2026

Proposals Due: April 6, 2026 – 5:00 PM EDT

1. Introduction

The Town of Brighton is seeking proposals from qualified contractors to install a new cold-climate heat pump system that will cover the occupied space. Due to the extreme cold temperatures experienced in Brighton during the winter months, the existing boiler system/wood stove will be retained to provide ambient temperature control with the heat pump system serving as the primary heating and only cooling option. Additionally, install remotely accessible, fully programmable thermostats for both the heat pump and existing hot water systems.

This project builds on recommendations identified in the Municipal Energy Resilience Program (MERP) Level I Energy Audit prepared by Bureau Veritas (December 2023), and is included as Appendix B. Funding for this work is provided through the Vermont Department of Buildings & General Services (BGS) under the Municipal Energy Resilience Program.

2. Project Overview

Building Summary: Brighton Town Garage

Year Built: 1999

Size: 8,000 square feet

Occupancy: 3 people – 5 days per week plus

Current Heating: The building is heated by a central boiler that feeds baseboard heaters and wood burning stove.

Energy Audit Recommendations:

1. Replace the existing 249 MBH #2 oil boiler with an air cooled cold-climate heat pump system. A heat pump will supply heating and cooling and will be appropriately sized for the space. *The Town also intends to retain either the boiler system or wood stove to maintain ambient temperatures throughout the building given the extremely cold winter temperatures experienced in the Brighton area.*

2. Installing remote accessible and programmable thermostats to better control the equipment's operating hours will yield additional energy savings and is also recommended.

3. Scope of Work

A. Heat Pump Installation

- Provide and install cold-climate, ENERGY STAR® rated air-source heat pump system, sized OR design system to meet needs of the space and occupants.
- Include both indoor and outdoor units with necessary refrigerant and electrical connections.
- Provide condensate management and all associated control wiring.
- Test, balance, and commission systems upon completion.
- Ensure all work complies with NFPA 70, Vermont State Building and Electrical Codes, and manufacturer specifications.

B. Replace/Install Smart Thermostats

- Replace/Install building thermostats with remotely-accessible, 24-hour fully programmable smart thermostats.

4. Contractor Qualifications

- Demonstrated experience installing cold-climate heat pumps.
- Licensed and insured to work in Vermont.
- Familiarity with Efficiency Vermont incentives preferred

5. Proposal Requirements

Proposals must include:

- Company Information: Name, address, contact person, and proof of licensing and insurance.
- Project Approach: Work plan and proposed schedule.
- Equipment Specifications: Manufacturer, model numbers, and performance ratings (HSPF/ SEER).
- Cost Proposal: Itemized pricing for: - Heat pump system (equipment, installation, controls) – Smart Thermostat (materials and labor)
- References: At least two recent similar projects.

6. Site Visit

Site visits are optional but encouraged. Contractors should contact the Town Manager, Mike Strait at (802) 266-1054 or townmanager@brightonvt.gov in order to schedule your visit so that access can be provided to all areas of the building.

7. Evaluation Criteria

Proposals will be evaluated based on:

- Cost competitiveness (40%)
- Technical approach and understanding of project goals (25%)
- Experience and references (20%)
- Schedule and availability (15%)

8. Submission Instructions

Submit proposals electronically (PDF) or mail envelope marked “Brighton Town Garage HVAC RFP” to:

Michael Strait
 Town Manager
 Town of Brighton
 PO Box 377
 49 Mill St. Ext.
 Island Pond, VT 05846

TownManager@brightonvt.gov

Late submissions will not be accepted.

9. Schedule

Milestone	Date
RFP Issued	March 12, 2026
Site Visit	March 16, 2026 – April 6, 2026
Proposals Due	April 6, 2026
Contractor Selected	April 15, 2026
Work Begins	Spring/Summer 2026
Work Completed By	September 30, 2026

10. Questions

Questions must be submitted in writing by March 26th to TownManager@brightonvt.gov . Responses will be shared with all bidders.

This RFP is issued in accordance with Municipal Energy Resilience Program regulations. The selected contractor will be expected to comply with all applicable laws, codes, and standards. The Town reserves the right to waive any formalities or minor defects, or to accept any or reject all bids.

Appendix A: Bid Form

Town of Brighton Garage HVAC Project Bid Form

Item	Description	Quantity/Model	Unit Cost	Total Cost
1	Heat Pump Installation			
2	Smart Thermostats			
Total Bid Price				\$ _____

Company Name: _____

Address: _____

Contact Person: _____

Phone: _____

Email: _____

Signature: _____

Date: _____

Contractor Checklist

- Completed Bid Form (Appendix A)
- Project approach and proposed timeline
- Proof of insurance and licensing
- Equipment specifications (model, efficiency ratings)
- References from at least two similar projects
- Proposed total project cost (itemized)
- Signed and dated proposal

Issued by:

Town of Brighton, Vermont

Municipal Energy Resilience Program Project

Contact: Mike Strait, TownManager@brightonvt.gov



Town of Brighton
VERMONT

APPENDIX B

MUNICIPAL ENERGY RESILIENCE PROGRAM LEVEL I ENERGY AUDIT

prepared for

Vermont Department of Buildings & General Services

133 State Street, 5th Floor,
Montpelier, Vermont 05633-5801

Mr. Brian Sewell

And

The City of Brighton



**BUREAU
VERITAS**

PREPARED BY:

Bureau Veritas
6021 University Blvd. Suite 200
Ellicott City, Maryland 21043
800.733.0660
www.us.bureauveritas.com

BV CONTACT:

Ivan Meneses, PE, CEM
Program Manager
800.733.0660 x 7296267
Ivan.Meneses@bureauveritas.com

BV PROJECT #:

161246.23R000-006.267

DATE OF REPORT:

December 5, 2023

ON SITE DATE:

September 28, 2023



Town Garage
825 Railroad Street
Brighton, Vermont 05846

Bureau Veritas

TABLE OF CONTENTS

Certification	1
1. Executive Summary	2
1.1. Energy Conservation Measures	2
1.2. Assumptions	4
2. Site Utilities	6
2.1. Utility Rates.....	6
2.2. Site Utility Analysis	6
2.3. On-site Utility Storage.....	6
2.4. On-site Generation	6
2.5. On-site Electric Vehicle Charging.....	7
3. Introduction	8
4. Facility Overview and Existing Conditions	9
4.1. Building Occupancy and Point of Contact	9
4.2. Building Envelope.....	9
4.3. Building Heating, Ventilating, and Air-Conditioning (HVAC)	10
4.4. Building Lighting	11
4.5. Building Appliances & Laundry.....	11
4.6. Building Domestic Water	11
4.7. Recommended 5 year Phased Approach Table	12
4.8. Recommended Energy Conservation Measures Scope of Work.....	13
5. Recommended Operations and Maintenance Plan	16
6. Appendices	18



Certification

Bureau Veritas has completed an MERP Level I Energy Audit in accordance with the State of Vermont ACT 172 at Town Garage located at 825 Railroad Street, Brighton, Vermont 05846. Bureau Veritas visited the site on September 28, 2023.

The assessment was performed at the Client's request using methods and procedures consistent with MERP Level I Energy Audit and using methods and procedures as outlined in Bureau Veritas's Proposal.

This report has been prepared for and is exclusively for the use and benefit of the Client identified on the cover page of this report. The purpose for which this report shall be used shall be limited to the use as stated in the contract between the client and Bureau Veritas.

This report, or any of the information contained therein, is not for the use or benefit of, nor may it be relied upon by any other person or entity, for any purpose without the advance written consent of Bureau Veritas. Any reuse or distribution without such consent shall be at the client's or recipient's sole risk, without liability to Bureau Veritas.

Estimated installation costs are based on Bureau Veritas's experience on similar projects and industry standard cost estimating tools including *RS Means and Whitestone CostLab*. In developing the installed costs, Bureau Veritas also considered the area correction factors for labor rates for Brighton, Vermont. Since actual installed costs may vary widely for particular installation based on labor and material rates at time of installation, Bureau Veritas does not guarantee installed cost estimates and shall in no event be liable should actual installed costs vary from the estimated costs herein. We strongly encourage the owner to confirm these cost estimates independently. Bureau Veritas does not guarantee the costs savings estimated in this report. Bureau Veritas shall in no event be liable should the actual energy savings vary from the savings estimated herein.

Bureau Veritas certifies that Bureau Veritas has no undisclosed interest in the subject property and that Bureau Veritas's employment and compensation are not contingent upon the findings or estimated costs to remedy any deficiencies due to deferred maintenance and any noted component or system replacements.

Any questions regarding this report should be directed to Ivan Meneses, PE, CEM, at 800.733.0660, ext. 7296267.

Prepared by: Nick Thompson,
Project Manager

Reviewed by:



Ivan MENESES, PE, CEM
Sr. Energy Project Manager

1. Executive Summary

The purpose of this MERP Level I Energy Audit is to provide Vermont Department of Buildings and General Services and Brighton Town Garage with energy efficiency opportunities at the facility and specific recommendations for Energy and water Conservation Measures (ECM's). Information obtained from these analyses may be used to support a future application to an Energy Conservation Program, Utility grants towards energy conservation, or as a basis for replacement of equipment or systems.

Building Type / Name	# Bldgs	# Stories	Year Built/ Renovated	Building Size	Estimated Occupancy
Town Garage	1	1	1999	8,000 SF	1

The study included a review of the building's construction features, historical energy and water consumption and costs, review of the building envelope, HVAC equipment, heat distribution systems, lighting, and the building's operational and maintenance practices.

Summary of Existing Energy Performance	
Percentage Area Cooled	0%
Percentage Area Heated	100%

1.1. Energy Conservation Measures

Bureau Veritas has evaluated 5 Energy Conservation Measures (ECMs) for this property. The savings for each measure is calculated using standard engineering methods followed in the industry. A 10% discount in energy savings was applied to account for the interactive effects amongst the ECMs. In addition to the consideration of the interactive effects, Bureau Veritas has applied a 15% contingency to the implementation costs to account for potential cost overruns during the implementation of the ECMs.

For this site we did not receive utility data. Therefore, we estimated the energy consumption shown in Section 2.2.

Below is a general description of the recommended energy conservation measures:

HVAC SYSTEM: Bureau Veritas recommends replacing the existing 249 MBH gas boiler with an 12.5 ton air cooled heat pump system. A heat pump will supply heating and cooling and will be appropriately sized for the space. Installing a programmable thermostat to better control the equipment's operating hours will yield additional energy savings and is also recommended.

SOLAR AND BATTERY STORAGE SYSTEMS: Bureau recommends installing a 26 kW Photovoltaic system with an annual capacity of 31,161 kW/Hour. The array should BE INSTALLED on the roof since unshaded space is unavailable for a ground mounted system. A 35 kilowatt/hour battery storage system with an eight-hour energy storage capacity should also be installed. The battery storage system should be installed near the main electric panel. These recommendations are for planning purposes. Qualified electrical and structural engineers must be consulted to determine the electrical requirements and to evaluate the load-bearing capacity of the roof structure.

ELECTRICAL VEHICLE CHARGING STATIONS: Bureau Veritas recommends installing an EV charging station. There appears to be sufficient electrical capacity to add one 40-AMP breaker to accommodate an EV charging station. However, a qualified electrician must be consulted to determine to verify the electrical requirements.

WEATHER STRIPPING: Bureau Veritas recommends installing door sweeps to reduce air leakage. Caulking the doors, windows and wall joints is also recommended.

ATTIC INSULATION: Bureau veritas recommended adding insulation to the current R-10 level in the attic space to equal the ASHRAE standard of R-49.

WATER HEATER: Bureau Veritas recommends changing the existing indirect water heater to an heat pump heated water heater.

The following table summarizes the recommended ECMs in terms of description, investment cost, energy consumption reduction, and cost savings.

Evaluated Non- Renewable Energy Conservation Measures: Financial Impact	
Total Projected Initial ECM Investment	\$166,254
Estimated Annual Cost Savings Related to ECMs	\$7,956
Estimated Annual Cost Savings- Electricity	\$805
Estimated Annual Cost Savings- Propane	\$0
Estimated Annual Cost Savings- Natural Gas	\$0
Estimated Annual Cost Savings- Fuel Oil	\$7,098
Net Effective ECM Payback	21 Years
Estimated Annual Energy Savings	464%
Estimated Annual Utility Cost Savings <i>(excluding water)</i>	56%

Onsite Renewable Energy Generation Solar Photo Voltaic Analysis	
Estimated number of panels	65
Estimated kW Rating	26 kW
Potential Annual kWh Produced	31,161 kWh
Battery Size	35
% of Current Electricity Load	64%
Investment Cost	\$101,489
Estimated Energy Cost Savings	\$5,609
Payback without Incentives	18 Years
Payback with All Incentives	18 Years
Battery Size	35 KW-hr
Battery Cost	\$45,589

Energy Conservation Measures Sorting:

1. Simple Payback Period –The number of years required for the cumulative value of energy or water cost savings less future non-fuel or non-water costs to equal the investment costs of the building energy or water system, without consideration of discount rates. ECMs with a payback period greater than the Expected Useful Life (EUL) of the project are not typically recommended, as the cost of the project will not be recovered during the lifespan of the equipment. These ECMs are recommended for implementation during future system replacement. At that time, replacement may be evaluated based on the premium cost of installing energy efficient equipment.

$$\text{Simple Payback} = \frac{\text{Initial Cost}}{\text{Annual Savings}}$$

1.2. Assumptions

Bureau Veritas has made the following assumptions in calculation of the Energy Conservation Measures.

- Building operating hours are assumed to be 56 hours per week.
- The facility occupancy is assumed to be one person.
- Annual Heating Equipment Operating Hours are derived from estimated consumption and equipment input rates to be 1200 hours/year.
- Annual Cooling Equipment Operating Hours are derived from estimated future consumption and equipment input rates to be 816 hours/year.

List of Recommended Energy Conservation Measures For Brighton Town Garage											
1	Title:	Description of ECM	Projected Initial Investment	Estimated Annual Energy & Water Savings					Total Estimated Annual Cost Savings	Simple Payback	
				(a)	Natural Gas	Propane	No.2 Oil	Electricity			Water
				(\$)	(Therms)	(Gallons)	(Gallons)	(kWh)			(kGal)
1	Replace HVAC Units With Electric /Heat Pump HVAC Units	Replace (1x) 249MBH - 0 Ton RTU With (1x) 12.5 Tons - Heat Pump RTU System;	\$26,794	0	0	1,760	-23,460	0	\$671	39.92	
2	Improve Attic Insulation Levels	Improve existing attic insulation from R-10 to R-R-49by adding Batt Insulation	\$9,200	0	0	352	0	0	\$989	9.31	
3	Control External Air Leakage In Commercial Buildings	Perform air sealing of building through Installing 130x linear feet of door sweeps, Re-caulking 130x linear feet of joints	\$2,756	0	0	352	0	0	\$1,028	2.68	
4	Replace Existing Water Heater With New Energy Efficient Units	Replace 1x 40kBTus No. 2 Oil water heaters with 40-Gal,4-kW 2EF Heat Pump water heater	\$3,105	0	0	225	-2,730	0	\$135	23.03	
5	Reduce HVAC Hours of Operation	Self Learning Smart Thermostat - (4x) Sensors	\$1,224	0	0	147	0	0	\$408	3.00	
Totals for No/Low Cost Items			\$0	0	0	0	0	0	\$0	0.00	
Total For Capital Cost			\$144,568	0	0	2,837	4,971	14	\$8,840	16.35	
		<i>Interactive Savings Discount @ 10%</i>		0	0	-284	-497	-1	-\$884		
		<i>Total Contingency Expenses @ 15%</i>	\$21,685								
Total for Improvements			\$166,254	0	0	2,553	4,474	13	\$7,956	20.90	



2. Site Utilities

2.1. Utility Rates

The following utility rates were used for the purposes of savings analysis.

Average Utility Rates				
Electricity	Natural Gas	Wood	Propane / No.2 Oil	Water & Sewer
Average Rate	Average Rate	Average Rate	Average Rate	Blended Rate
\$0.18/kWh	\$1.20/therm	\$0.10/lbs	\$2.78/Gal	\$ 16.11/kgal

2.2. Site Utility Analysis

Utility Analysis						
UTILITY TYPE	UTILITY PROVIDER	METER QUANTITY	ENERGY / WATER USES	ANNUAL CONSUMPTION	EST / ACT	ANNUAL COST
Electric	Vermont electrical co-op	One	Includes lighting, appliances, plug loads, ventilation, process loads, computers, domestic hot water.	38,400	EST	\$6,912
No. 2 Oil	Unknown	-	Heating	2570	EST	\$7,146

2.3. On-site Utility Storage

Onsite Utility Storage	
Fossil Fuel Storage	
No.2 Oil	1X – 275 Gallon Above Ground Tanks

2.4. On-site Generation

Site Utilities	
Facility Electric Service Size	225 AMPS
Onsite Transformer	Pole-mounted

Electric Meter Location	Exterior pole mount
-------------------------	---------------------

2.5. On-site Electric Vehicle Charging

Onsite Electric Vehicle Charging	
Installed Chargers	None
Recommendations:	Install one EV charger
Onsite EV Charging Potential	
Spare AMPS at Main Electrical Panel	80 AMPS
Proposed Location of EV Charger	North end of the building
Recommended Charger Type	Type II
Proposed Quantity of Chargers	2 (40AMPS/Charger)
Potential Initial Investment	\$4,500/Charger

3. Introduction

The purpose of this Energy Audit is to provide Vermont Department of Buildings and General Services and Town Garage with a baseline of energy usage, the relative energy efficiency of the facility, and specific recommendations for Energy Conservation Measures. Information obtained from these analyses may be used to support a future application to an Energy Conservation Program, Federal and Utility grants towards energy conservation, as well as support performance contracting, justify a municipal bond-funded improvement program, or as a basis for replacement of equipment or systems.

The energy audit consisted of an onsite visual assessment to determine current conditions, itemize the energy consuming equipment (i.e. Boilers, Make-Up Air Units, DWH equipment); review lighting systems both exterior and interior; and review efficiency of all such equipment. The study also included interviews and consultation with operational and maintenance personnel. The following is a summary of the tasks and reporting that make up the Energy Audit portion of the report.

The following is a summary of the tasks and reporting that make up the Energy Audit portion of the report.

Energy and Water Using Equipment

- Bureau Veritas has surveyed the maintenance facilities and mechanical rooms to document utility-related equipment, including heating systems, cooling systems, air handling systems and lighting systems.

Building Envelope

- Bureau Veritas has reviewed the characteristics and conditions of the building envelope, checking insulation values and conditions. This review also includes an inspection of the condition of walls, windows, doors, roof areas, insulation and special use areas.

Recommendations for Energy Savings Opportunities

- Based on the information gathered during the on-site assessment, the utility rates, as well as recent consumption data and engineering analysis, Bureau Veritas has identified opportunities to save energy and provide probable construction costs, projected energy/utility savings and provide a simple payback analysis.

Energy Audit Process

- Interviewing staff and review plans and past upgrades
- Performing an energy audit for each use type. Performing a preliminary evaluation of the utility system
- Making preliminary recommendations for system energy improvements and measures
- Estimating initial cost

Reporting

The Bureau Veritas Energy Audit Report includes:

- A comprehensive study identifying all applicable Energy Conservation Measures (ECMs) and priorities, based on initial cost.

4. Facility Overview and Existing Conditions

4.1. Building Occupancy and Point of Contact

Facility Schedule	
Operational Weeks/Year	52
Estimated Facility Occupancy	One
Hours of Operations/Week	56

Facility Schedule	
Point of Contact Name	Noah Bond
Point of Contact Title	Town Manager
Point of Contact – Contact Number	802.343.8946

4.2. Building Envelope

The building envelope consists of the exterior shell, made up of the walls, windows, roof, and floor. The envelope provides building integrity and separates the exterior from the interior conditioned space.

Building Foundation	
Item	Description
Foundation	Slab on grade with integral footings
Basement and Crawl Space	None
Basement Wall Insulation	None

Primary Roof			
Finish	Metal	Coatings	None
Type/Geometry	Gable	Roof Drains	Edge drainage to ground
Maintenance	Outside Contractor	Main Ventilation Source	Gable end vents
Insulation	Cellulose blown	Roof/Attic Insulation	R-10



Exterior Walls	
Type	Location
Primary Finish	Wood siding
Secondary Finish	None
Wall Insulation	Fiberglass batts

Exterior Windows		
Location	Window Framing	Glazing
Main	Aluminum-framed, operable	Double glaze

Exterior Doors		
Building Doors		Quantity
Main Entrance Doors	Metal, insulated	2
Overhead Doors	Aluminium	3

Door Comments:

The *Condition* field in the chart above refers to the condition of the perimeter weatherstripping and/or caulking around the doors and frames. Minimal weather stripping was observed, and all in fair to poor condition.

4.3. Building Heating, Ventilating, and Air-Conditioning (HVAC)

Overall System Description:

The building is heated by a central boiler that feeds baseboard heaters and wood burning stove.

Building Central Heating System	
Primary Heating System Type	Hot water boilers
Heating Fuel	Fuel oil
Location of Major Equipment	Mechanical rooms
Space Served by System	Entire building
Heating System Input Capacity	249 MBH
Manufacturer's Rated Efficiency	87%
Heating Plant Age	1995
Heating Plant Condition	Fair



HVAC Comments:

A wood burning stove/furnace supplements the heating in the main bay and a window unit is in the office.

4.4. Building Lighting

Space Lighting:

Suspended pendant and surface mounted industrial light fixtures containing (18)LED and (5)T8/2 4 foot bulbs provide interior lighting in the buildings. The fixtures are currently equipped with electronic ballasts. The industrial fixtures are located in the office and mezzanine areas and the LED are located throughout the bay area.

Lighting Controls:

The facility does have any automatic lighting controls on internal light fixtures. The lights in the bay areas are controlled by automatic lighting controls that mainly consists of ceiling mounted occupancy sensors.

Emergency Lighting:

The EXIT signs in the facility consist of LED based fixtures.

Exterior Lighting:

Surface-mounted light fixtures on the exterior walls provide the exterior building with site illumination.

The exterior lighting primarily consists of CFL and LED fixtures.

4.5. Building Appliances & Laundry

There are no appliances.

4.6. Building Domestic Water

Central Domestic Hot Water	
Components	Water heaters
Fuel	No. 2 oil
Distribution Pumps	None
Supplementary Storage Tanks	None
Domestic Hot Water System Input Capacity	35 Gal
Manufacturer's Rated Efficiency	78%
Hot Water Piping	Insulated
Quantity	One

Plumbing Comments:

There is no other plumbing equipment in the building.



4.7. Recommended 5 year Phased Approach Table.

Recommended 5 Year Plan			
Description of ECM	Priority	Net Projected Initial Investment	Projected Completion Term
Replace HVAC Units With Electric /Heat Pump HVAC Units	Priority 1	\$ 26,795	< 12 months
Improve Attic Insulation Levels	Priority 1	\$ 9,200	< 12 months
Control External Air Leakage In Commercial	Priority 1	\$ 2,756	< 12 months
Replace Existing Water Heater With New Energy	Priority 1	\$ 3,105	< 12 months
Reduce HVAC Hours of Operation	Priority 1	\$ 1,224	< 12 months
Install Fixed Tilt Solar Photovoltaic System	Priority 3	\$ 101,489	3-5 years



4.8. Recommended Energy Conservation Measures Scope of Work.

- **Replace Heating Units with Heat Pumps Cooling and Heating System:** The objective is to replace the current fossil fuel HVAC system by a heat pump system. Perform commercial load calculation in accordance with the current version of ANSI/ACCA Manual N (Commercial Load Calculation) or equivalent using interior design temperatures of 75 degrees for cooling and 70 degrees for heating. Perform commercial load calculation in accordance with the current version of ANSI/ACCA Manual N (Commercial Load Calculation) or equivalent using interior design temperatures of 75 degrees for cooling and 70 degrees for heating. Room by room load calculations will be performed when installing a new duct system or in retro-commissioning projects. Select commercial equipment in accordance with the current version of ANSI/ACCA Manual CS (Commercial Applications, Systems and Equipment) or equivalent. Select cooling equipment capable of meeting the sensible and latent load of the building that is not sized more than 115% of total load or next available size. Select heating equipment of the lowest capacity required to meet the design heating load and provide the air movement required by any air conditioning equipment installed. Select system that is ENERGY STAR® certified or equivalent. Select outdoor units that are corrosion-protected for marine climate zones. Demolish existing HVAC units. Procure and install new like-for-like high efficiency Heat Pump units (SEER 15). If on the roof, reuse existing curbs on the roof, provide curb adapter if necessary. Install new disconnect switch and conduit to the new units in accordance with NFPA 70. Locate unit to provide clearance on all sides and top according to manufacturer specifications and service access according to applicable code. Situate outdoor unit on a non-wicking equipment pad. Install exterior ductwork using rigid, corrosion-resistant metal insulated to a minimum of R-12. Test and balance all modified systems. Perform duct leak remediation as required per SMACNA standards. Install smoke detector if required by local State Code. Connect new HVAC equipment to new Thermostat. Commission equipment and controls. Install smoke detectors inside the supply duct plenum of systems that move more than 2,500 cubic feet per minute (CFM) in accordance with the applicable building code
- **Control External Air Leakage In Commercial Buildings:** The objective is to control external air leakage in commercial buildings. Weatherstripping: Place weatherstripping around all openings. Where external vents are used – such as for a clothes dryer – select vent covers that are as airtight as possible. Apply weatherstripping snugly against both surfaces. The material should compress when the window or door is shut. Choose the appropriate door sweeps and thresholds for the bottom of the doors. Weatherstrip the entire door jamb. Apply one continuous strip along each side. Make sure the weatherstripping meets tightly at the corners. Use a thickness that causes the weatherstripping to press tightly between the door and the door jamb when the door closes without making it difficult to shut. Replace all caulking on windows. Caulking: Most caulk is designed to fill a joint that is no more than ½-inch deep and ½-inch wide, although products called elastomeric caulks can fill larger gaps. Joints that are the correct width, but too deep, such as the gap between a window frame and the rough opening, can be packed with backer rod or stuffed with fiberglass insulation first and the remaining space filled with caulk. For larger gaps, expanding foam is an effective sealant. Dispensed from canisters through a gun, foam will fill gaps up to a couple of inches wide. However, larger gaps may need to be covered with a scrap of solid wood or OSB first and then foam applied in the remaining gaps. Install mastic on electrical boxes, wired penetrations and unused knockouts. Window and door frames should be sealed to the wall frames with caulk, foam or flexible tape depending on the size of the gap. Casement and awning windows are preferable from an air leakage standpoint because the sash presses against the gasket when closed. When possible locate attic hatches and crawl space access doors in places where they will not penetrate

the air barrier. For example, the attic hatch can often be located in a garage or gable end wall. Crawl space access can be placed in an outside wall below the level of the insulated floor.

- **Improve Attic Insulation Levels:** The objective is to install batt insulation in the attic space. Ensure space can be safely insulated. Verify that installation area is intact, able to support insulation weight, and air sealed. Remove any existing insulation or vapor barrier materials from the installation area that are installed improperly. Select insulation materials that have a flame spread and smoke development index of 25/450 or less when tested in accordance with [ASTM E84](#) or [UL 723](#). Install batt insulation to prescribed R-value in every joist bay in full contact with the air barrier and all sides of the cavity without gaps, voids, compressions, or misalignments, if batt contains a facing material install it in contact with the conditioned space.
- **Install Fixed Tilt Solar Photovoltaic System:** The objective is to properly install a photovoltaic system. Verify current electrical panel and service line infrastructure is in good condition, compliant with codes, and of sufficient electrical capacity (Amps) to accommodate interconnection of solar power. Verify position of spare (unused) breaker or space to install new breaker in panel for solar power interconnection. If a roof installation is planned, verify that the roof will support the installation (e.g., dead load, wind load) and that the current roof covering is less than 5 years old. Verify that the type of roof is suitable for solar installation (e.g. not slate or wood shingle). The roof understructure shall be inspected and evaluated for support of PV system. Any reinforcements, such as blocking between rafters, shall be completed before load of PV system is applied. If a roof installation is planned, the roof shall be inspected, cleaned and any necessary repairs shall be made. Design the size of PV system to serve the prescribed load. Prepare electrical one line drawing. Prepare layout drawings showing location and connections of all equipment. Provide list (make, model) of all equipment. Design PV system layout to provide safe access around PV modules as required by codes and standards, and required clearances around balance-of-system components such as inverter and switchgear. Locate PV Modules to minimize shading factor and maximize solar gain, but not interfere with existing systems or appliance operation (e.g., chimneys, vents, exhaust terminations). Secure approval of design by utility and secure interconnection agreement to operate utility-connected PV system. Secure electrical permit to install and operate PV system from Authority Having Jurisdiction (AHJ) (e.g. County building Dept.). Installer shall meet the requirements of AHJ. Secure the mounting structures to the roof following manufacturer instructions. Install flashing to make all roof penetrations weather-tight and leak-proof using instructions and materials specified by manufacturer. Install inverters and disconnects in a safe and accessible location, inverter shall be located in the shade when specified by manufacturer's instructions. Install solar panels on the mounting structures according to the manufacturer's instructions. The installation shall comply with all applicable codes and standards adopted by Authority Having Jurisdiction, including but not limited to: National Electric Code (NEC), International Residential Code (IRC), IEEE 1547 Standard for Interconnecting Distributed Resources with Electric Power Systems, UL 1703 Standard for Flat-Plate Photovoltaic Modules and Panels, Manufacturer's installation and operation manuals. Install all electrical components according to the NEC and authority having jurisdiction. Fasten wires with wire ties and conduit as per design and installation instructions. The system shall be connected to the electrical grid at a location and in a method approved by the utility. Monitor the system energy delivery for a minimum of 12 months and compare results with predicted energy production. Provide documentation to the building owner, including: copy of the installation and operation manual, electrical diagrams and schematics, certificate of inspection and approval, system performance benchmark data. Perform electrical tests to verify proper operation and system performance. Tests include open circuit voltage, operating current, resistance of grounding system (should be <25 ohms), and resistance of electrical insulation (should be

>1 Megohm). Measured voltage shall be compared to reference voltage corrected for temperature. Measured current shall be compared to reference current corrected for insolation (sunlight level). The PV modules and inverter shall be warranted by the manufacturer. Provide occupants/owners with user's manual, warranty information, installation instructions, and installer contact information. Whole system shall be warranted by the installer for a period of at least 1 year. The warranty shall cover defects in materials and workmanship.

- **Replace Water Heater:** The objective is to select a water heater system that is efficient, durable and properly sized. Select a water heater that: has an Energy Factor (EF) of 0.93 or better fits in the installation space with required clearances and provides sufficient hot water for the home and occupants. Ensure that old equipment is permanently removed from service, in accordance with federal and local laws and regulations. Install water heater in compliance with applicable code (e.g., NFPA 70, IRC, IBC, IMC) and manufacturer specifications. Provide a level working space not less than 30" in length and 30" in width in front of the control side of the appliance. Install appliance and plumbing to allow for inspection, maintenance, and replacement of the appliance and its components, without disturbing other installed equipment, controls, piping, and components, other than what requires repair/replacement. Ensure that anode rod is accessible for replacement. If appliance is installed in or above conditioned space or in a location where water damage could occur, install a drain pan according to local plumbing code. Drain pan to the exterior of the building. Install a separate water cut-off valve for both the hot and cold water lines. Set discharge temperature to not exceed 120 degrees or as prescribed by local code.
- **Replace Thermostat / Reduce Hours of Operation:** The objective is to replace thermostat by a 24 hour fully programmable unit. Verify that sufficient number of thermostat wires is available to meet the needs of the replacement unit and the existing system. Select a double-setback programmable thermostat that allows for full functionality of the installed system (supplementary heat, emergency heat, fan only, ventilation control, etc.). Install thermostat where it accurately reflects the temperature and humidity of the zone which it controls (i.e., not exposed to extreme temperatures, radiant heat sources, warm/cold walls, or drafts). Connect supplementary heat to second-stage heating terminal in accordance with manufacturer specifications. Install and connect outdoor temperature sensor that is compatible with the thermostat in accordance with manufacturer specifications. Calculate and select an optimum thermal balance point for supplementary heat operation in accordance with ANSI/ACCA Manual S and manufacturer specifications. Program the thermostat to match the equipment and control board settings per manufacturer specifications. Set time delay for fan start in accordance with manufacturer specifications and as appropriate for the climate zone (e.g., no time delay for hot humid climates, longer time delay for cold climates). Program the thermostat setbacks to a schedule that accommodates the occupant and reduces overall run time.

5. Recommended Operations and Maintenance Plan

The quality of the maintenance and the operation of the facility's energy systems have a direct effect on its overall energy efficiency. Energy-efficiency needs to be a consideration when implementing facility modifications, equipment replacements, and general corrective actions. The following is a list of activities that should be performed as part of the routine maintenance program for the property.

Building Envelope

- ✓ Ensure that the building envelope has proper caulking and weather stripping.
- ✓ Patch holes in the building envelope with foam insulation and fire rated caulk around combustion vents
- ✓ Inspect building vents semiannually for bird infestation
- ✓ Inspect windows monthly for damaged panes and failed thermal seals
- ✓ Repair and adjust automatic door closing mechanisms as needed.

Heating and Cooling

- ✗ Pilots lights on furnaces and boilers be turned off in summer
- ✗ All preventive maintenance should be performed on all furnaces and boilers, which would include cleaning of burners and heat exchanger tubes.
- ✗ Ensure that the combustion vents exhaust outside the conditioned space and the vent dampers are functional
- ✗ Ensure that the control valves are functioning properly before start of every season
- ✗ Ensure steam traps are functional before start of each heating season
- ✗ Ensure use of chemical treatment for boiler make up water
- ✗ Ensure boiler outside temperature re-set is set to 55F
- ✓ Ensure the duct work in unconditioned space is un-compromised and well insulated
- ✗ Duct cleaning is recommended every 10 years. This should include sealing of ducts using products similar to 'aero-seal'
- ✗ Ensure use of economizer mode is functional and used
- ✓ Ensure that the outside air dampers actuators are operating correctly
- ✗ Ensure air coils in the AHU and FCA's are pressure washed annually
- ✓ Return vents should remain un-obstructed and be located centrally
- ✓ Temperature settings reduced in unoccupied areas and set points seasonally adjusted.
- ✗ Evaporator coils and condenser coils should be regularly cleaned to improve heat transfer
- ✓ Change air filters on return vents seasonally. Use only filters with 'Minimum Efficiency Rating Value'(MERV) of 8

Central Domestic Hot Water Heater

- ✗ Never place gas fired water heaters adjacent to return vents so as to prevent flame roll outs
- ✗ Ensure the circulation system is on timer to reduce the losses through re-circulation
- ✗ Ensure all hot water pipes are insulated with fiberglass insulation at all times
- ✓ Replacement water heater should have Energy Factor (EF)>0.9
- ✓ Tank-type water heaters flushed monthly

Lighting Improvements

- ✓ Utilize bi-level lighting controls in stairwells and hallways.
- ✓ Use LED replacement lamps
- ✓ Clean lighting fixture reflective surfaces and translucent covers.
- ✓ Ensure that timers and/or photocells are operating correctly on exterior lighting
- ✓ Use occupancy sensors for offices and other rooms with infrequent occupancy

Existing Equipment and Replacements

- ✓ Ensure that refrigerator and freezer doors close and seal correctly
- ✓ Ensure kitchen and bathroom exhaust outside the building and the internal damper operates properly
- ✓ Ensure that bathroom vents exhaust out
- ✓ Office/computer equipment either in the “sleep” or “off” mode when not used

Key

x	Maintenance Measure is Not Applicable For the Given Facility
✓	Maintenance Measure is Applicable For the Given Facility

6. Appendices

- APPENDIX A: Photographic Record
- APPENDIX B: Site and Floor Plans
- APPENDIX C: Mechanical Inventory
- APPENDIX D: Energy Conservation Measures Calculations
- APPENDIX E: Other Supporting Documents



Appendix A:

Photographic Record



Photographic Overview



1 - FRONT ELEVATION



2 - LEFT ELEVATION



3 - REAR ELEVATION



4 - RIGHT ELEVATION



5 - ROOF



6 - INTERIOR AREA



Photographic Overview



7 - BOILER



8 - WOOD FURNACE



9 - NO.2 OIL TANK



10 - WATER HEATER



11 - ELECTRICAL PANEL



12 - ELECTRIC METER



Appendix B:

Site and Floor Plans



Site Plan



	Project Number	Project Name
	161246.23R000-006.267	Town Garage
	Source	On-Site Date
	Google	September 28, 2023



Appendix C:

Mechanical Equipment Inventory



Appendix D: Energy Conservation Measures Calculations

UIC	Reduce HVAC Hours of Operation	
EAC3	Location: Throughout BLDG Air Handlers	
Attributes:	Self Learning Smart Thermostat - (4x) Sensors	
No. of Sensors Affected :	4	Qty.
Select Type of Recommendation:	Self Learning Smart Thermostat (Select)	
<i>(Selection Based on Type of Property)</i>		
Heating Load Calculation		Cooling Load Calculation
Select Type of Heating Fuel	No. 2 Oil (Select)	Select Type of Cooling Fuel (Default)
Estimated Current Annual Energy Consumption For Winter Heating	2,570 Gallons	Estimated Current Annual Energy Consumption For Summer Cooling
	Weekdays Weekends	Weekdays Weekends
Day Time Set Back Hours	10.00 0.00	Day Time Set Back Hours
Night Time Set Back Hours	14.00 24.00	Night Time Set Back Hours
Hours Without Set Back	0.00 0.00	Hours Without Set Back
Typical Indoor Temp	72.00 °F	Typical Indoor Temp
Temp Set Point With Set Back During Day Time	70.00 °F	Temp Set Point With Set Back During Day Time
Temp Set Point With Set Back During Night Time	65.00 °F	Temp Set Point With Set Back During Night Time
Average Heating Set Point	66.49 °F	Average Cooling Set Point
Savings Per Degree Set Back For Heating Season <i>(Industry Standard, 2004)</i>	3%	Savings Per Degree Set Back For Cooling Season <i>(Industry Standard, 2004)</i>
Estimated Annual Heating Energy Consumption	356,000 kBtu	Estimated Annual Cooling Energy Consumption
Estimated New Annual Heating Energy Consumption	297,133 kBtu	Estimated New Annual Cooling Energy Consumption
Estimated Annual Heating Energy Savings	147 Gallons	Estimated Annual Cooling Energy Savings
Cost Analysis		
Average Annual Cost of Heating Fuel:	\$2.78 /Gal	Estimated Investment Per Sensor: <i>(Includes Material, Labor & Installation Costs)</i>
Average Annual Cost of Electricity:	\$0.18 /kWh	Total Estimated Cost For All Sensors:
Estimated Annual Heating Cost Savings:	\$408 \$\$	Total Estimated Cost Savings From All Sensors:
Estimated Annual Cooling Cost Savings:	\$0 \$\$	Estimated Simple Pay Back Period
Type of Recommendation	Capital Cost ECM Recommendation	

Disclaimer: PREPARED BY BUREAU VERITAS (BV). FEBRUARY 2022 INFORMATION CONTAINED IN THIS DOCUMENT IS PRIVILEGED AND CONFIDENTIAL "TRADE SECRET" AND IS THE SOLE PROPERTY OF BV. THIS MATERIAL MUST BE CONSIDERED PRIVILEGED AND CONFIDENTIAL BY ALL PARTIES PRIVY.

ECM DESCRIPTION:

Turning off energy-consuming systems when they are not needed is the most basic energy conservation technique. When a building is occupied intermittently, energy savings can be realized by minimizing the time the heating or cooling system is operated when the building is closed. Building control algorithms should be implemented to delay startup until the last moment and to shut down as early as possible.

Because of the thermal inertia of both the building structure and its heating and cooling equipment, preheat or precool time is almost always required to raise or lower the space temperature to the desired level before the occupants return. This start-up time depends on the outdoor environment, the thermal response of the building, and the thermal performance of the space conditioning equipment. Similarly, the thermal inertia of the building maintains the indoor temperature at a comfortable level for a short period of time after the equipment is shut off. It allows the system to be turned off before the end of an occupied period. An optimum start/stop control accounts for these factors.

SUMMARY

Initial Investment: \$1,224 Simple Payback Period: 3.00 Yrs
Annual Energy Cost Saving: \$408

UIC		Control External Air Leakage In Commercial Buildings	
EAE4A	Location:		
Attributes:	Perform air sealing of building through Installing 130x linear feet of door sweeps, Re-caulking 130x linear feet of joints		
ENTER EXISTING CONDITION			
Insert Existing Estimated Air Change Rate/Hr (ACH 1): <small>(Existing Air Changes Per Hour, 3 is very leaky and 0.35 ideal)</small>	<input type="text" value="1.50"/>	Cubic Feet/Min (CFM 1):	<input type="text" value="1,600"/>
Insert Proposed Estimated Air Change Rate/Hr (ACH 2):	<input type="text" value="0.75"/>	Cubic Feet/Min (CFM 2):	<input type="text" value="800"/>
Estimated Space Volume Under Consideration	<input type="text" value="64,000"/>	Cu.Ft	
WINTER		SUMMER	
Select Type of Heating Fuel	<input type="text" value="No. 2 Oil"/> (Select)	Is The Building Cooled?	<input type="text" value="No"/>
Estimated Annual Heating Plant Efficiency	<input type="text" value="85.00"/> %	Estimated Annual Cooling Plant Efficiency	<input type="text" value=""/>
Annual Heating Degree Days(HDD):	<input type="text" value="7,187"/>	Annual Cooling Degree Days(CDD):	<input type="text" value="445"/>
Estimated Total Annual Input Heating Energy Savings	<input type="text" value="352"/> Gallons	Estimated Total Annual Input Cooling Energy Savings	<input type="text" value="0"/> kWh
Cost/Unit of Heating Fuel:	<input type="text" value="\$2.78"/> \$/Gal	Cost/Unit For Electricity	<input type="text" value="\$0.18"/> \$\$
Estimated Annual Heating Cost Savings	<input type="text" value="\$979"/> \$\$	Estimated Annual Cooling Cost Savings	<input type="text" value="\$0"/> \$\$
Cost Analysis			
Install Flush Mounted, Vinyl Door Sweeps ?	<input type="text" value="Yes"/>	Total Length of Door Sweeps to Be Installed: <small>(3.5' Standard Width Door)</small>	<input type="text" value="130"/> LF
Install Window Air Conditioner Covers For Winter:	<input type="text" value="No"/>	Number of Air Conditioner Covers To Be Installed: <small>(Covers would meet HUD Chapter-12 Energy Conservation Compliance Section 329C)</small>	<input type="text" value=""/>
Estimated Annual O&M Savings	<input type="text" value="\$49"/>	Estimated Length of Joints To Be Re-Caulked: <small>(Includes Demolition and Re-Caulking)</small>	<input type="text" value="100"/> LF
Total Estimated Annual Cost Savings	<input type="text" value="\$1,028"/>	Total Cost For Controlling Air Leakage	<input type="text" value="\$2,756"/>
Simple Pay Back Period	<input type="text" value="2.68"/> Yrs	<i>Type of Recommendation</i>	<input type="text" value="Capital Cost ECM Recommendation"/>

Disclaimer: PREPARED BY BUREAU VERITAS (BV). FEBRUARY 2022 INFORMATION CONTAINED IN THIS DOCUMENT IS PRIVILEGED AND CONFIDENTIAL "TRADE SECRET" AND IS THE SOLE PROPERTY OF BV. THIS MATERIAL MUST BE CONSIDERED PRIVILEGED AND CONFIDENTIAL BY ALL PARTIES PRIVY.

ECM DESCRIPTION:

One of the most commonly used methods for reducing air leakage through building structures is caulking and weather stripping.

Particularly effective measures include caulking cracks around windows and door frames and weather stripping around windows and doors. Weather-stripping and caulking of doors and windows, helps in thermally isolating of the building with the outside atmosphere. This prevents the infiltration of external un-conditioned air along with moisture and humidity into the conditioned space at the same time, prevents the conditioned air from escaping out. A precisely thermally isolated building directly affects the cooling and heating load on the facilities HVAC system as it has to put in less effort in maintaining the desired temperature inside the facility. As per ASHRAE a well insulated and ventilated building should have an air change rate not more than 0.35 per hour.

In order to ensure proper thermal isolation of the property, BV recommends ensuring that the weather-stripping and caulking of all external doors and windows remains intact. It is also recommended that door sweeps be installed under all the doors opening into conditioned space. Any visible cracks between the window frame and wall should be plugged by caulking.

In case of building with window airconditioners, BV recommends use of interior/exterior window airconditioner covers so as to prevent cold air drafts into the conditioned space during the winter so as to save on heating costs.

SUMMARY:

Initial Investment: \$2,756 Simple Pay Back Period: 2.68 Yrs
Annual Energy Cost Savings: \$1,028

UIC	Improve Attic Insulation Levels	
EAE3	Location:	
Attributes:	Improve existing attic insulation from R-10 to R-49 by adding Batt Insulation	
ENTER EXISTING CONDITION		
ASHRAE Climatic Zone	<input type="text" value="Zone-6"/>	ASHRAE 90.1 Attic- Insulation Requirement: <input type="text" value="R-49"/>
Enter Total Surface Area Under Consideration:	<input type="text" value="8,000"/> Sq.Ft	Existing Net Effective R-Value: (Sq.Ft deg F/btu) <input type="text" value="10"/>
Proposed Type of Insulation To Be Added:	<input type="text" value="Batt Insulation"/> (Select)	Proposed Insulation Recommendation: <input type="text" value="Full Upgrade"/> (Select)
Recommended Level of Insulation To Be Added:	<input type="text" value="R-49"/>	Proposed Net Effective R-Value: (Sq.Ft deg F/btu) <input type="text" value="49"/> <small>(Post Retrofit-Final Net Insulation)</small>
ENTER CLIMATIC & SYSTEM DATA		
Annual Cooling Degree Days (CDD):	<input type="text" value="445"/>	Estimated Annual Cooling Plant Efficiency (EER): <input type="text" value=""/> EER
Annual Heating Degree Days (HDD):	<input type="text" value="7,187"/>	Estimated Annual Heating Plant Efficiency: % <input type="text" value="72.60"/> %
WINTER		SUMMER
Select Type of Heating Fuel	<input type="text" value="No. 2 Oil"/> (Select)	Is the Property Cooled ? <input type="text" value="No"/> (Select)
Annual Conduction Losses From Existing Insulation	<input type="text" value="137,996"/> kBtu	Annual Conduction Losses From Existing Insulation <input type="text" value="8,544"/> kBtu
Annual Conduction Losses From Proposed Insulation	<input type="text" value="28,162"/> kBtu	Annual Conduction Losses From Proposed Insulation <input type="text" value="1,744"/> kBtu
Savings In Conduction Losses After Adding Insulation	<input type="text" value="109,834"/> kBtu	Savings In Conduction Losses After Adding Insulation <input type="text" value="0"/> kBtu
Estimated Total Annual Input Heating Energy Savings	<input type="text" value="352"/> Gallons	Estimated Total Annual Input Cooling Energy Savings <input type="text" value="0"/> kWh
Cost of Heating Fuel/Unit:	<input type="text" value="\$2.78"/> \$/Gal	Cost of Electricity/Unit <input type="text" value="\$0.18"/> \$\$
Annual Heating Cost Savings	<input type="text" value="\$979"/> \$\$	Annual Cooling Cost Savings <input type="text" value="\$0"/> \$\$
COST ANALYSIS		
Estimated O&M Savings	<input type="text" value="\$10"/> \$\$	Estimated Cost To Add Insulation on <input type="text" value="\$8,000"/>
Total Estimated Annual Cost Savings	<input type="text" value="\$989"/> \$\$	Estimated Total Installation Cost <input type="text" value="\$9,200"/> \$\$
Simple Pay Back Period	<input type="text" value="9.31"/> Years	<i>Type of Recommendation</i> <input type="text" value="Capital Cost ECM Recommendation"/>

Disclaimer: PREPARED BY BUREAU VERITAS (BV). FEBRUARY 2022 INFORMATION CONTAINED IN THIS DOCUMENT IS PRIVILEGED AND CONFIDENTIAL "TRADE SECRET" AND IS THE SOLE PROPERTY OF BV. THIS MATERIAL MUST BE CONSIDERED PRIVILEGED AND CONFIDENTIAL BY ALL PARTIES PRIVY.

ECM DESCRIPTION:

The amount of heat conduction through ceiling and roof is proportional to its overall heat transfer coefficient (commonly called the U-factor) and the temperature difference between the conditioned space and its surrounding, modified by the effect of solar intensity and wind velocity on the exterior surfaces. One of the most effective ways to reduce heat transfer through ceilings and roofs is to retard heat conduction by adding insulation.

Where the existing roof is sound and directly accessible from an attic or ceiling void, polyurethane foam or mineral fiber may be sprayed on the underside, with rigid batt or other applicable insulation for the inside surface. Insulation, typically fiber-glass batt, may also be laid on the top of a ceiling, taking care not to cover up light fixtures.

Unimembers can degrade the performance of the insulation up to 20%, and resultant condensation can cause insulated structural the structure to deteriorate. Therefore, care should be taken to properly insulate the structural members. Often more energy can be conserved by insulating the ceiling rather than the roof unless the attic is being used for special storage, frequent access is required, or a moderate attic temperature is desired. However, if only the ceiling is insulated, any ducting or piping should be insulated to avoid excessive heat transfer or freezing. It is important to be sure that the attic is ventilated by providing one to two inches of ventilation area per square foot of attic.

Summary:

Initial Investment:	\$9,200	Simple Payback Period:	9.31 Yrs
Annual Energy Cost Savings:	\$989		

UIC	Replace HVAC Units With Electric /Heat Pump HVAC Units
EAH-15	Location:
Attributes:	Replace (1x) 249MBH - 0 Ton RTU With (1x) 12.5 Tons - Heat Pump RTU System;

	<i>Garage</i>	<i>Specify Location</i>	<i>Specify Location</i>	<i>Specify Location</i>
Heating System				
Number of Heating Systems to be replaced	1 Qty	Qty	Qty	Qty
Heating Fuel:	No. 2 Oil	Natural Gas	Natural Gas	Natural Gas
Heating System Capacity (Each)	249 MBH	MBH	MBH	MBH
De-rated AFUE rating For Each Heating System	72.60 %	%	%	%
Estimated Annual Operating Hours:	1,224 Hrs	Hrs	Hrs	Hrs
Estimated Annual Energy Use from All Heating Systems	1,760 Gallons	0 Therms	0 Therms	0 Therms
Cooling				
Unit has Cooling?	No	Yes	Yes	Yes
Refrigerant in Cooling System				
Cooling Capacity for Each Unit	Btuh	Btuh	Btuh	Btuh
EER of the Existing Cooling System:	EER	EER	EER	EER
Estimated Annual Operating Hours:	Hrs	Hrs	Hrs	Hrs
Energy Consumption From All Existing Air conditioner:	0 kWh	0 kWh	0 kWh	0 kWh

Proposed System

Proposed System:	12.5 Tons - Heat Pump RTU			
Proposed Cooling System Capacity	150,000 Btuh	0 Btuh	0 Btuh	0 Btuh
EER of Proposed Air-Conditioning System:	15.00 EER	0.00 EER	0.00 EER	0.00 EER
Total Energy Consumption For Proposed RTU - Cooling:	9,384 kWh	0 kWh	0 kWh	0 kWh
Proposed Heating System Input:	11.50 kW	0.00 kW	0.00 kW	0.00 kW
COP of Proposed RTU Heating System:	3.20 COP	0.00 COP	0.00 COP	0.00 COP
Total Energy Consumption For Proposed RTU Heat:	14,076 kWh	0 kWh	0 kWh	0 kWh
Estimated Annual Energy Consumption From All Systems:	23,460 kWh	0 kWh	0 kWh	0 kWh

Savings Analysis

Annual Energy Savings From Heating Systems:	195,793 kBtuh	0 kBtuh	0 kBtuh	0 kBtuh
Annual kWh savings for all Air conditioner:	-9,384 kWh	0 kWh	0 kWh	0 kWh
Material Cost For All RTU(s):	\$21,250	\$0	\$0	\$0
Labor Cost for All RTU(s):	\$5,544	\$0	\$0	\$0
Installed Cost for all RTU(s):	\$26,794	\$0	\$0	\$0
Total Investment	\$26,794	\$0	\$0	\$0
Estimated Annual Energy Cost Savings:	-\$1,018	\$0	\$0	\$0
Estimated Annual Energy Savings:	163,775 kBtuh	0 kBtuh	0 kBtuh	0 kBtuh
Total Utility Savings	0 Therms	0 Gal	1,760 Gal	-23,460 kWh
Total Initial Investment:	\$26,794	Total Annual Utility Cost Savings:	-\$1,018	
Simple Payback:	-26.32 Yrs			
Type of Recommendation	Capital Cost ECM Recommendation			

UIC		Replace Existing Water Heater With New Energy Efficient Units			
EAD3	Location:				
Attributes:	Replace 1x 40kBtus No. 2 Oil water heaters with 40-Gal,4-kW 2EF Heat Pump water heater				
Step 1	Existing Water Heater Details	<i>Indirect Water Heater</i>	<i>Specify Location Here</i>	<i>Specify Location Here</i>	<i>Specify Location Here</i>
	Number of Water Heaters Being Replaced:	1			
	Select Existing Hot Water Heater Fuel	No. 2 Oil	Electric	Natural Gas	Natural Gas
	Insert Energy Factor of Existing Water Heater	0.60 EF			
	Input Existing Water Heater Input Rating	40.00 kBtus			4.50 kBtus
	Select One Method For Calculation	Annual Heating Hours	Annual Heating Hours	Annual DWH Load	Annual DWH Load
	Insert Average Annual Hours of Operation	780 hrs	450 hrs		
	Annual Water Heater Energy Consumption/Heater	225 Gallons	0 kWh	#DIV/0! hrs	0 hrs
	Total Estimated Annual Energy Consumption For all Heaters	225 Gallons	0 kWh	0 Therms	0 Therms
	Total Estimated Annual Operating Energy Costs For all Heaters	\$626 \$	\$0 \$	\$0 \$	\$0 \$
Step 2	Proposed New Water Heater				
	Proposed Quantity of Water Heaters:	1			
	Proposed Hot Water Heater Fuel	Heat Pump			
	Capacity of the Proposed New Water Heater	40-Gal,4-kW			
	Energy Factor of Proposed Water Heater	2.00 EF	0.00 EF	0.00 EF	0.00 EF
	Proposed Water Heater Input Rating	3.50 kW	0.00 kW	0.00 kW	0.00 kW
	Annual kBtuh Consumption For All The Proposed Water Heaters	9,360 kBtuh	0 kBtuh	0 kBtuh	0 kBtuh
	Estimated Annual Water Heater Fuel Consumption (All Heaters)	2,730 kwh	0	0	0
	Estimated Total Annual Energy Costs	\$491	\$0	\$0	\$0
Step 3	Energy & Cost Saving Calculation				
	Estimated Material Cost of New Water Heater	\$1,380	\$0	\$0	\$0
	Estimated Labor Cost of New Water Heater	\$1,725	\$0	\$0	\$0
	Total Estimated Installation Cost	\$3,105	\$0	\$0	\$0
	Total Estimated Annual Cost Savings	\$135	\$0		\$0
	Total Annual Cost Savings:	\$135	Total Initial Investment::	\$3,105	
	Simple Pay Back Period	23.03			
	Type of Recommendation	Capital Cost ECM Recommendation			

UIC	Install Fixed Tilt Solar Photovoltaic System
EAR1	Location:
Attributes:	Install fixed tilt 26KW Solar Photovoltaic System consisting of 26KW Rooftop Fixed Array PV System;

Select State: **Vermont** Electric Rate: **\$0.18** \$/KWH Annual Electric Consumption: **38,400** KWh

Roof No.	Description	Location of the Array	DC System Size Per Roof	Estimated Battery Size	PV System Sizing For All Roofs	Estimated Number of 400 Watt PV Panels:	Total Estimated Annual Electricity Generated/ Roof	Total Estimated Electricity Generated (All Roofs)	Total Cost Savings	Installation Cost:	Simple Pay Back Period without Incentives	One Time Potential Utility or State Incentives	One Time Potential Federal Incentives	Annual Potential Incentives and Rebates		Simple Pay Back Period with All Incentives
			kW	KW-H	kW		kWh	kWh			Yrs		Federal Tax Credit	Federal REPI Incentive	Solar Renewable Certificates (SRECS)- (\$/MWH)	Years
1	Rooftop Fixed Array	Main Bldg	26	35	26	65	31,161	31,161	\$5,609	\$101,489	18.1	\$0	26%	\$0.00	Varies by State	18.1
2					0	0	0	0	\$0	\$0		\$0	\$0	\$0	\$0	
3					0	0	0	0	\$0	\$0		\$0	\$0	\$0	\$0	
4					0	0	0	0	\$0	\$0		\$0	\$0	\$0	\$0	
5					0	0	0	0	\$0	\$0		\$0	\$0	\$0	\$0	
6					0	0	0	0	\$0	\$0		\$0	\$0	\$0	\$0	
7					0	0	0	0	\$0	\$0		\$0	\$0	\$0	\$0	
8					0	0	0	0	\$0	\$0		\$0	\$0	\$0	\$0	
9					0	0	0	0	\$0	\$0		\$0	\$0	\$0	\$0	
10					0	0	0	0	\$0	\$0		\$0	\$0	\$0	\$0	
		0			26	65	31,161.0	31,161	\$5,609	\$101,489	18.09	\$0	\$0	\$0	\$0	18.09

Solar Rooftop Photovoltaic Analysis	
Total Number of Roofs	0
Estimated Number of Panels	65
Estimated KW Rating	26 kW
Potential Annual KWh Produced	31,161 kWh
% of Current Electricity Load	81.1%

Financial Analysis	
Investment Cost	\$101,489
Estimated Energy Cost Savings	\$5,609
Potential Rebates	\$0
Potential Annual Incentives	\$0
Payback without Incentives	18.1 years
Incentive Payback but without SRECS	18.1 years
Payback with All Incentives	18.1 years

Appendix E:

Other Supporting Documents



Glossary of Terms and Acronyms - Energy Audits

ECM – Energy Conservation Measures are projects recommended to reduce energy consumption. These can be No/Low cost items implemented as part of routine maintenance or Capital Cost items to be implemented as a capital improvement project.

Initial Investment – The estimated cost of implementing an ECM project. Estimates typically are based on R.S. Means Construction cost data and Industry Standards.

Annual Energy Savings – The reduction in energy consumption attributable to the implementation of a particular ECM. These savings values do not include the interactive effects of other ECMs.

Cost Savings – The expected reduction in utility or energy costs achieved through the corresponding reduction in energy consumption by implementation of an ECM.

Simple Payback Period – The number of years required for the cumulative value of energy or water cost savings less future non-fuel or non-water costs to equal the investment costs of the building energy or water system, without consideration of discount rates.

EUL – Expected Useful Life is the estimated lifespan of a typical piece of equipment based on industry accepted standards.

RUL – Remaining Useful Life is the EUL minus the effective age of the equipment and reflects the estimated number of operating years remaining for the item.

SIR – The savings-to-investment ratio is the ratio of the present value savings to the present value costs of an energy or water conservation measure. The numerator of the ratio is the present value of net savings in energy or water and non-fuel or non-water operation and maintenance costs attributable to the proposed energy or water conservation measure. The denominator of the ratio is the present value of the net increase in investment and replacement costs less salvage value attributable to the proposed energy or water conservation measure. It is recommended that energy-efficiency recommendations be based on a calculated SIR, with larger SIRs receiving a higher priority. A project typically is recommended only if the SIR is greater than or equal to 1.0, unless other factors outweigh the financial benefit.

Life Cycle Cost – The sum of the present values of (a) Investment costs, less salvage values at the end of the study period; (b) Non-fuel operation and maintenance costs; (c) Replacement costs less salvage costs of replaced building systems; and (d) Energy and/or water costs.

Life Cycle Savings – The sum of the estimated annual cost savings over the EUL of the recommended ECM, expressed in present value dollars.

Building Site Energy Use Intensity – The sum of the total site energy use in thousands of Btu per unit of gross building area. Site energy accounts for all energy consumed at the building location only not the energy consumed during generation and transmission of the energy to the site.

Building Source Energy Use Intensity – The sum of the total source energy use in thousands of Btu per unit of gross building area. Source energy is the energy consumed during generation and transmission in supplying the energy to your site.

Building Cost Intensity – This metric is the sum of all energy use costs in dollars per unit of gross building area.

Greenhouse Gas Emissions – Although there are numerous gases that are classified as contributors to the total for Greenhouse Emissions, the scope of this energy audit focuses on carbon dioxide (CO₂). Carbon dioxide enters the atmosphere through the burning of fossil fuels (oil, natural gas, and coal), solid waste, trees and wood products, and also as a result of other chemical reactions (e.g., manufacture of cement).