



Town of Brighton

VERMONT

Town of Brighton, Vermont

Request for Proposal

Heat Pump Installation for Municipal Building

Issued: March 12, 2026

Proposals Due: April 6, 2026 – 5:00 PM EDT

1. Introduction

The Town of Brighton is seeking proposals from qualified contractors to install a new cold-climate heat pump system that will all cover the occupied space. Due to the extreme cold temperatures experienced in Brighton during the winter months, the existing boiler system will be retained to provide ambient temperature control with the heat pump system serving as the primary heating and only cooling option. Additionally, install remotely accessible, fully programmable thermostats for both the heat pump and existing hot water systems.

This project builds on recommendations identified in the Municipal Energy Resilience Program (MERP) Level I Energy Audit prepared by Bureau Veritas (December 2023), and is included as Appendix B. Funding for this work is provided through the Vermont Department of Buildings & General Services (BGS) under the Municipal Energy Resilience Program.

2. Project Overview

Building Summary: Brighton Municipal Building

Year Built: 1889, Renovated 2011

Size: 30,000 square feet encompassing the basement and two upper floors, the third floor of the municipal building is currently unoccupied.

Occupancy: 12-20 people – 5 days per week plus

Current Heating: Two fuel oil boilers supply hot water for the hydronic loop system consisting of baseboard heaters and ceiling mounted heaters. A ductless mini-split system supplies air conditioning for the bank and a second one provides air conditioning to the library.

Energy Audit Recommendations:

1. Replace the two existing 170 MBH #2 oil boiler and existing mini-split units with a 40-ton air cooled cold-climate heat pump system. A heat pump will supply heating and cooling and will be appropriately sized for the space. *Due to a historic preservation easement on the exterior of*

the structure, this option is likely not feasible as it would require metal ducting on the exterior of the structure. The Town will consider options that could meet the easement provisions, but it is more likely that we will be looking at a ductless system due to its less intrusive construction. The Town also intends to retain the boiler system to maintain ambient temperatures throughout the building given the extremely cold winter temperatures experienced in the Brighton area.

2. Installing remote accessible and programmable thermostats to better control the equipment's operating hours will yield additional energy savings and is also recommended.

3. Scope of Work

A. Heat Pump Installation

- Provide and install cold-climate, ENERGY STAR® rated air-source heat pump system, sized OR design system to meet needs of the space and occupants.
- Include both indoor and outdoor units with necessary refrigerant and electrical connections.
- Provide condensate management and all associated control wiring.
- Test, balance, and commission systems upon completion.
- Ensure all work complies with NFPA 70, Vermont State Building and Electrical Codes, and manufacturer specifications.

B. Replace/Install Smart Thermostats

- Replace/Install building thermostats with remotely-accessible, 24-hour fully programmable smart thermostats.

4. Contractor Qualifications

- Demonstrated experience installing cold-climate heat pumps.
- Licensed and insured to work in Vermont.
- Familiarity with Efficiency Vermont incentives preferred

5. Proposal Requirements

Proposals must include:

- Company Information: Name, address, contact person, and proof of licensing and insurance.
- Project Approach: Work plan and proposed schedule.
- Equipment Specifications: Manufacturer, model numbers, and performance ratings (HSPF/SEER).
- Cost Proposal: Itemized pricing for: - Heat pump system (equipment, installation, controls) – Smart Thermostat (materials and labor)
- References: At least two recent similar projects.

6. Site Visit

Site visits are optional but encouraged. Contractors should contact the Town Manager, Mike Strait at (802) 266-1054 or townmanager@brightonvt.gov in order to schedule your visit so that access can be provided to all areas of the building.

7. Evaluation Criteria

Proposals will be evaluated based on:

- Cost competitiveness (40%)
- Technical approach and understanding of project goals (25%)
- Experience and references (20%)
- Schedule and availability (15%)

8. Submission Instructions

Submit proposals electronically (PDF) or mail envelope marked “Brighton Town Hall HVAC RFP” to:

Michael Strait
Town Manager
Town of Brighton
PO Box 377
49 Mill St. Ext.
Island Pond, VT 05846

TownManager@brightonvt.gov

Late submissions will not be accepted.

9. Schedule

Milestone	Date
RFP Issued	March 12, 2026
Site Visit	March 16, 2026 – April 6, 2026
Proposals Due	April 6, 2026
Contractor Selected	April 15, 2026
Work Begins	Spring/Summer 2026
Work Completed By	September 30, 2026

10. Questions

Questions must be submitted in writing by March 26th to TownManager@brightonvt.gov . Responses will be shared with all bidders.

This RFP is issued in accordance with Municipal Energy Resilience Program regulations. The selected contractor will be expected to comply with all applicable laws, codes, and standards. The Town reserves the right to waive any formalities or minor defects, or to accept any or reject all bids.

Appendix A: Bid Form

Town of Brighton Municipal Building HVAC Project Bid Form

Item	Description	Quantity/Model	Unit Cost	Total Cost
1	Heat Pump Installation			
2	Smart Thermostats			
Total Bid Price				\$ _____

Company Name: _____

Address: _____

Contact Person: _____

Phone: _____

Email: _____

Signature: _____

Date: _____

Contractor Checklist

- Completed Bid Form (Appendix A)
- Project approach and proposed timeline
- Proof of insurance and licensing
- Equipment specifications (model, efficiency ratings)
- References from at least two similar projects
- Proposed total project cost (itemized)
- Signed and dated proposal

Issued by:

Town of Brighton, Vermont

Municipal Energy Resilience Program Project

Contact: Mike Strait, TownManager@brightonvt.gov



Town of Brighton
VERMONT

APPENDIX B

MUNICIPAL ENERGY RESILIENCE PROGRAM LEVEL I ENERGY AUDIT

prepared for

Vermont Department of Buildings & General Services

133 State Street, 5th Floor,
Montpelier, Vermont 05633-5801

Mr. Brian Sewell

And

The Town of Brighton



**BUREAU
VERITAS**

PREPARED BY:

Bureau Veritas
6021 University Blvd. Suite 200
Ellicott City, Maryland 21043
800.733.0660
www.us.bureauveritas.com

BV CONTACT:

Ivan Meneses, PE, CEM
Program Manager
800.733.0660 x 7296267
Ivan.Meneses@bureauveritas.com

BV PROJECT #:

161246.23R000-005.267

DATE OF REPORT:

December 5, 2023

ON SITE DATE:

September 28, 2023



Town Hall
49 Mill Street Extension
Brighton, Vermont 05846

Bureau Veritas

TABLE OF CONTENTS

Certification	1
1. Executive Summary	2
1.1. Energy Conservation Measures	2
1.2. Assumptions	4
2. Site Utilities	6
2.1. Utility Rates.....	6
2.2. Site Utility Analysis	6
2.3. On-site Utility Storage.....	6
2.4. On-site Generation	7
3. Introduction	8
4. Facility Overview and Existing Conditions	9
4.1. Building Occupancy and Point of Contact.....	9
4.2. Building Envelope.....	9
4.3. Building Heating, Ventilating, and Air-Conditioning (HVAC)	11
4.4. Building Lighting	11
4.5. Building Appliances & Laundry.....	12
4.6. Building Domestic Water	12
4.7. Recommended 5 year Phased Approach Table	13
4.8. Recommended Energy Conservation Measures Scope of Work.....	14
5. Recommended Operations and Maintenance Plan	17
6. Appendices	19



Certification

Bureau Veritas has completed an MERP Level I Energy Audit in accordance with the State of Vermont ACT 172 at Town Hall located at 49 Mill Street Extension, Brighton, Vermont 05846. Bureau Veritas visited the site on September 28, 2023.

The assessment was performed at the Client's request using methods and procedures consistent with MERP Level I Energy Audit and using methods and procedures as outlined in Bureau Veritas's Proposal.

This report has been prepared for and is exclusively for the use and benefit of the Client identified on the cover page of this report. The purpose for which this report shall be used shall be limited to the use as stated in the contract between the client and Bureau Veritas.

This report, or any of the information contained therein, is not for the use or benefit of, nor may it be relied upon by any other person or entity, for any purpose without the advance written consent of Bureau Veritas. Any reuse or distribution without such consent shall be at the client's or recipient's sole risk, without liability to Bureau Veritas.

Estimated installation costs are based on Bureau Veritas's experience on similar projects and industry standard cost estimating tools including *RS Means* and *Whitestone CostLab*. In developing the installed costs, Bureau Veritas also considered the area correction factors for labor and material rates for Brighton, Vermont. Since actual installed costs may vary widely for particular installation based on labor and material rates at time of installation, Bureau Veritas does not guarantee installed cost estimates and shall in no event be liable should actual installed costs vary from the estimated costs herein. We strongly encourage the owner to confirm these cost estimates independently. Bureau Veritas does not guarantee the costs savings estimated in this report. Bureau Veritas shall in no event be liable should the actual energy savings vary from the savings estimated herein.

Bureau Veritas certifies that Bureau Veritas has no undisclosed interest in the subject property and that Bureau Veritas's employment and compensation are not contingent upon the findings or estimated costs to remedy any deficiencies due to deferred maintenance and any noted component or system replacements.

Any questions regarding this report should be directed to Ivan Meneses, PE, CEM, at 800.733.0660, ext. 7296267.

Prepared by: Larry Wright,
Project Manager

Reviewed by:



Ivan MENESES, PE, CEM
Sr. Energy Project Manager

1. Executive Summary

The purpose of this MERP Level I Energy Audit is to provide Vermont Department of Buildings and General Services and Brighton Town Hall with energy efficiency opportunities at the facility and specific recommendations for Energy and water Conservation Measures (ECM's). Information obtained from these analyses may be used to support a future application to an Energy Conservation Program, Utility grants towards energy conservation, or as a basis for replacement of equipment or systems.

Building Type/Name	# Building	# Stories	Year Built/ Renovated	Building Size	Estimated Occupancy
Town Hall	1	3 with basement	YOC:1889 YOR: 2011	30,000 square feet	12

The study included a review of the building's construction features, historical energy and water consumption and costs, review of the building envelope, HVAC equipment, heat distribution systems, lighting, and the building's operational and maintenance practices.

Summary of Existing Energy Performance	
Percentage Area Cooled	20%
Percentage Area Heated	100%

1.1. Energy Conservation Measures

Bureau Veritas has evaluated 6 Energy Conservation Measures (ECMs) for this property. The savings for each measure is calculated using standard engineering methods followed in the industry. A 10% discount in energy savings was applied to account for the interactive effects amongst the ECMs. In addition to the consideration of the interactive effects, Bureau Veritas has applied a 15% contingency to the implementation costs to account for potential cost overruns during the implementation of the ECMs.

For this site we did not receive utility data. Therefore, we estimated the energy consumption shown in Section 2.2.

Below is a general description of the recommended energy conservation measures:

HVAC SYSTEM: Bureau Veritas recommends replacing the two existing 170 MBH #2 oil boiler with a 40-ton air cooled heat pump system. A heat pump will supply heating and cooling and will be appropriately sized for the space. Installing a programmable thermostat to better control the equipment's operating hours will yield additional energy savings and is also recommended.

ATTIC INSULATION: Bureau veritas recommended adding insulation to the estimated R-10 level in the attic space to equal the ASHRAE standard of R-49.

WATER HEATER: Bureau Veritas recommends changing the existing 119 MBH # 2 oil water heater to three Heat Pump (4.5KW) water heaters.

SOLAR AND BATTERY STORAGE SYSTEMS: Bureau recommends installing a 72 kW Photovoltaic system with an annual capacity of 82,889 kW/Hour. The array should be installed on the roof as there is space available. A 77 kilowatt/hour battery storage system with a two-hour energy storage capacity should also be installed. The battery storage system should be installed near the main electric panel. These recommendations are for planning purposes. Qualified electrical and structural engineers must be consulted to determine the electrical requirements and to evaluate the load-bearing capacity of the roof structure.

ELECTRICAL VEHICLE CHARGING STATIONS: Bureau Veritas recommends installing an EV charging station. There does not appear to be sufficient electrical capacity to add a 40-AMP breaker to accommodate an EV charging station. However, a qualified electrician must be consulted to determine to verify the electrical requirements.



The following table summarizes the recommended ECMs in terms of description, investment cost, energy consumption reduction, and cost savings.

Evaluated Non- Renewable Energy Conservation Measures: Financial Impact	
Total Projected Initial ECM Investment	\$451,036
Estimated Annual Cost Savings Related to ECMs	\$16,447
Estimated Annual Cost Savings- Electricity	\$9,085
Estimated Annual Cost Savings- Propane	\$0
Estimated Annual Cost Savings- Natural Gas	\$0
Estimated Annual Cost Savings- Fuel Oil	\$7,324
Net Effective ECM Payback	27.4. Years
Estimated Annual Energy Savings	160%
Estimated Annual Utility Cost Savings <i>(excluding water)</i>	28%

Onsite Renewable Energy Generation Solar Photo Voltaic Analysis	
Estimated number of panels	179
Estimated kW Rating	71 kW
Potential Annual kWh Produced	82,889 kWh
% of Current Electricity Load	24.6%
Investment Cost	\$253,875
Estimated Energy Cost Savings	\$14,920
Payback without Incentives	17 Years
Payback with All Incentives	17 Years
Battery Size	77 KW-hr
Battery Cost	\$99,934

Energy Conservation Measures Sorting:

1. Simple Payback Period –The number of years required for the cumulative value of energy or water cost savings less future non-fuel or non-water costs to equal the investment costs of the building energy or water system, without consideration of discount rates. ECMs with a payback period greater than the Expected Useful Life (EUL) of the project are not typically recommended, as the cost of the project will not be recovered during the lifespan of the equipment. These ECMs are recommended for implementation during future system replacement. At that time, replacement may be evaluated based on the premium cost of installing energy efficient equipment.

$$\text{Simple Payback} = \frac{\text{Initial Cost}}{\text{Annual Savings}}$$

1.2. Other Considerations

ASHRAE LEVEL 2 AUDIT- Consider completing an ASHRAE Level 2 assessment to further evaluate additional energy conservation options such as lighting and water conservation measures among others.

BMS SYSTEM- Consider installing a Building Management System (BMS) to control the HVAC system and lighting throughout the building. A BMS system can provide substantial savings and improve occupant comfort.

OTHER SOURCES OF ENERGY: Consider conducting a study for evaluation of alternative sources of renewable energy such as geothermal, wind and hydrogen.

LED LIGHTING: Consider evaluating the feasibility of replacing all lighting with LED and installing lighting controls.

WATER CONSERVATION: Consider replacing all inefficient faucets and aerators with water sense labeled models.

1.3. Assumptions

Bureau Veritas has made the following assumptions in calculation of the Energy Conservation Measures.

- Building operating hours are assumed to be 40 hours per week.
- The facility occupancy is assumed to be 12 people.
- Annual Heating Equipment Operating Hours are derived from actual consumption and equipment input rates to be 1,027 hours/year.
- Annual Cooling Equipment Operating Hours are derived from actual consumption and equipment input rates to be 448 hours/year.

List of Recommended Energy Conservation Measures For Brihton Town Hall									
1	Title:	Description of ECM	Projected Initial Investment	Estimated Annual Energy & Water Savings			Total Estimated Annual Cost Savings	Simple Payback	
				(a)	No.2 Oil	Electricity			Water
				(\$)	(Gallons)	(kWh)			(kGal)
1	Title:	Improve Attic Insulation Levels	\$22,914	422	0	0	\$1,184	19.36	
	Attribute:	Improve existing attic insulation from R-10 to R-49 by adding Batt Insulation							
2	Title:	Reduce HVAC Hours of Operation	\$1,224	189	7,186	0	\$1,819	0.67	
	Attribute:	Self Learning Smart Thermostat - (4x) Sensors							
3	Title:	Install Fixed Tilt Solar Photovoltaic System	\$253,875	0	82,889	0	\$14,920	17.02	
	Attribute:	Install fixed tilt 71.6KW Solar Photovoltaic System consisting of 71.6kW Rooftop Fixed Array PV System;							
4	Title:	Replace Existing Water Heater With New Energy Efficient Units	\$8,025	663	-4,179	0	\$1,091	7.36	
	Attribute:	Replace 1x 119kBTus No. 2 Oil water heaters with 80-Gal,4.5-kW 3.45EF Heat Pump water heater							
5	Title:	Replace HVAC Units With Electric /Heat Pump HVAC Units	\$104,000	1,438	-29,816	0	-\$1,369	-75.97	
	Attribute:	Replace (2x) 170MBH - 9 Ton RTU With (2x) 40 Tons - Electric Heat RTU System;							
6	Title:	Control External Air Leakage In Commercial Buildings	\$2,168	216	0	0	\$630	3.44	
	Attribute:	Perform air sealing of building through installing 120x linear feet of door sweeps							
Totals for No/Low Cost Items			\$0	0	0	0	\$0	0.00	
Total For Capital Cost			\$392,205	2,927	56,080	0	\$18,274	21.46	
		Interactive Savings Discount @ 10%		-293	-5,608	0	-\$1,827		
		Total Contingency Expenses @ 15%	\$58,831						
Total for Improvements			\$451,036	2,635	50,472	0	\$16,447	27.42	



2. Site Utilities

2.1. Utility Rates

The following utility rates were used for the purposes of savings analysis.

Average Utility Rates				
Electricity	Natural Gas	Wood	Propane / No.2 Oil	Water & Sewer
Average Rate	Average Rate	Average Rate	Average Rate	Blended Rate
\$0.18/kWh	N/A	\$0.10/lbs	\$2.78/Gal	\$ 16.11/kgal

2.2. Site Utility Analysis

Utility Analysis						
UTILITY TYPE	UTILITY PROVIDER	METER QUANTITY	ENERGY / WATER USES	ANNUAL CONSUMPTION	EST / ACT	ANNUAL COST
Electric	Vermont Electric Co-op	3	Includes lighting, appliances, plug loads, ventilation, process loads, and computers.	296,135	EST	\$53,304
No. 2 Oil	Oil Supply	-	Serves heating system and domestic hot water.	2,108	EST	\$5,861

2.3. On-site Utility Storage

Onsite Utility Storage	
Fossil Fuel Storage	
No.2 Oil	2 x 330 Gallon Above Ground Tanks
Propane Gas	Not applicable
Wood Chips/Pellet	Not applicable

2.4. On-site Generation

Site Utilities	
Facility Electric Service Size	325 AMPS
Onsite Transformer	Pole-mounted
Electric Meter Location	Exterior Wall Mount

3. Introduction

The purpose of this Energy Audit is to provide Vermont Department of Buildings and General Services and Town Hall with a baseline of energy usage, the relative energy efficiency of the facility, and specific recommendations for Energy Conservation Measures. Information obtained from these analyses may be used to support a future application to an Energy Conservation Program, Federal and Utility grants towards energy conservation, as well as support performance contracting, justify a municipal bond-funded improvement program, or as a basis for replacement of equipment or systems.

The energy audit consisted of an onsite visual assessment to determine current conditions, itemize the energy consuming equipment (i.e. Boilers, Make-Up Air Units, DWH equipment); review lighting systems both exterior and interior; and review efficiency of all such equipment. The study also included interviews and consultation with operational and maintenance personnel. The following is a summary of the tasks and reporting that make up the Energy Audit portion of the report.

The following is a summary of the tasks and reporting that make up the Energy Audit portion of the report.

Energy and Water Using Equipment

- Bureau Veritas has surveyed all the spaces to document utility-related equipment, including heating systems, cooling systems, air handling systems and lighting systems.

Building Envelope

- Bureau Veritas has reviewed the characteristics and conditions of the building envelope, checking insulation values and conditions. This review also includes an inspection of the condition of walls, windows, doors, roof areas, insulation and special use areas.

Recommendations for Energy Savings Opportunities

- Based on the information gathered during the on-site assessment, the utility rates, as well as recent consumption data and engineering analysis, Bureau Veritas has identified opportunities to save energy and provide probable construction costs, projected energy/utility savings and provide a simple payback analysis.

Energy Audit Process

- Interviewing staff and review plans and past upgrades
- Performing an energy audit for each use type. Performing a preliminary evaluation of the utility system
- Making preliminary recommendations for system energy improvements and measures
- Estimating initial cost

Reporting

The Bureau Veritas Energy Audit Report includes:

- A comprehensive study identifying all applicable Energy Conservation Measures (ECMs) and priorities, based on initial cost.

4. Facility Overview and Existing Conditions

4.1. Building Occupancy and Point of Contact

Facility Schedule	
Hours of Operations/Week	40
Operational Weeks/Year	52
Estimated Facility Occupancy	12

Facility Schedule	
Point of Contact Name	Noah Bond
Point of Contact Title	Town Manager
Point of Contact – Contact Number	802.343.8947

4.2. Building Envelope

The building envelope consists of the exterior shell, made up of the walls, windows, roof, and floor. The envelope provides building integrity and separates the exterior from the interior conditioned space.

Building Foundation	
Item	Description
Foundation	Masonry foundation walls
Basement and Crawl Space	Concrete slab and masonry walls
Basement Wall Insulation	Cellulose Blown

Primary Roof			
Finish	Asphalt shingles	Coatings	None
Type/Geometry	Mansard	Roof Drains	Gutters and downspouts
Maintenance	Outside Contractor	Main Ventilation Source	Soffit vents
Insulation	Indeterminable	Roof/Attic Insulation	Unknown

Secondary Roof			
Finish	Modified bituminous	Coatings	None
Type/Geometry	Flat	Roof Drains	Internal drains
Maintenance	Outside Contractor	Main Ventilation Source	NA
Insulation	Rigid board	Roof/Attic Insulation	Unknown

Exterior Walls	
Type	Location
Primary Finish	Wood siding
Secondary Finish	None
Wall Insulation	Cellulose blown

Exterior Windows		
Location	Window Framing	Glazing
First and second floor	Aluminum-framed, fixed and operable	Double glaze
Third floor	Wood-framed, operable	Double glaze

Exterior Doors		
Building Doors		Quantity
Main Entrance Doors	Metal, insulated	1
Secondary Entrance Doors	Metal, insulated	2
Service Doors	Metal, insulated	3

Door Comments:

The *Condition* field in the chart above refers to the condition of the perimeter weatherstripping and/or caulking around the doors and frames. *The caulking, weather stripping, and conditions appear to be adequate.*

4.3. Building Heating, Ventilating, and Air-Conditioning (HVAC)

Overall System Description:

Two fuel oil boilers supply hot water for the hydronic loop system consisting of baseboard heaters and ceiling mounted heaters. The Ductless mini-split system supplies air conditioning for the bank only.

Split Systems	
Primary Components	Split system heat pumps
Cooling (if separate from above)	N/A
Heating Fuel	Electric
Location of Equipment	Building exterior
Spaces Served by Units	Bank
Manufacturer's Rated Efficiency	89 % EER
Refrigerant Used	R-410A
Quantity	3
Thermostat Control	Local - Programmable

Building Central Heating System	
Primary Heating System Type	Hot water boilers
Heating Fuel	Fuel oil
Location of Major Equipment	Mechanical rooms
Space Served by System	Entire building
Heating System Input Capacity	170,000 BTUH
Manufacturer's Rated Efficiency	80%
Heating Plant Age	2015
Heating Plant Condition	Fair

HVAC Comments:

The boilers, ductless split-system, baseboard heaters, and ceiling mounted heaters appear to be in good to fair condition. Replacement may be recommended for energy savings.

4.4. Building Lighting

Space Lighting:

Surface mounted wrap light suspended parabolic troffer, suspended pendant, recessed high hat, surface mounted socket lights, recessed prismatic troffer, surface mounted direct vanity sconce, surface mounted circular, surface mounted wrap around light fixtures containing incandescent bulbs, 4 pin CFL, CFL screw, LED, and LED linier retrofit bulbs provide interior lighting in the building.

The light fixtures are currently equipped with electronic ballasts. Vanity lights and circular fixtures are located in restrooms/shower rooms, recessed troffers and surface mounted troffers are located throughout halls and office areas. Suspended pendants and suspended troffers are located in the library, most socket fixtures are located in mechanical and storage spaces.

Lighting Controls:

The facility doesn't have any automatic lighting controls on internal light fixtures.

Emergency Lighting:

The EXIT signs in the facility consist of incandescent lamp-based fixtures.

Exterior Lighting:

Surface-mounted light fixtures on the exterior walls provide the exterior building with site illumination. The exterior lighting primarily consists of LED fixtures.

4.5. Building Appliances & Laundry

No Appliances found on the facility.

4.6. Building Domestic Water

Central Domestic Hot Water	
Components	Water heaters
Fuel	No. 2 oil
Distribution Pumps	None
Supplementary Storage Tanks	None
Domestic Hot Water System Input Capacity	Not provided
Manufacturer's Rated Efficiency	60% output/input
Hot Water Piping	Not insulated
Quantity	1

Plumbing Comments:

None



4.7. Recommended 5 year Phased Approach Table.

Recommended 5 Year Plan			
Description of ECM	Priority	Net Projected Initial Investment	Projected Completion Term
Improve Attic Insulation Levels	Priority 1	\$ 22,915	< 12 months
Reduce HVAC Hours of Operation	Priority 1	\$ 1,224	< 12 months
Install Fixed Tilt Solar Photovoltaic System	Priority 3	\$ 253,875	3-5 years
Replace Existing Water Heater With New Energy Efficient Units	Priority 1	\$ 8,025	< 12 months
Replace HVAC Units With Electric /Heat Pump HVAC Units	Priority 3	\$ 104,000	3-5 years
Control External Air Leakage In Commercial Buildings	Priority 2	\$ 2,168	1-3 years



4.8. Recommended Energy Conservation Measures Scope of Work.

- **Replace Heating Units with Heat Pumps Cooling and Heating System:** The objective is to replace the current fossil fuel HVAC system by a heat pump system. Perform commercial load calculation in accordance with the current version of ANSI/ACCA Manual N (Commercial Load Calculation) or equivalent using interior design temperatures of 75 degrees for cooling and 70 degrees for heating .Perform commercial load calculation in accordance with the current version of ANSI/ACCA Manual N (Commercial Load Calculation) or equivalent using interior design temperatures of 75 degrees for cooling and 70 degrees for heating . Room by room load calculations will be performed when installing a new duct system or in retro-commissioning projects. Select commercial equipment in accordance with the current version of ANSI/ACCA Manual CS (Commercial Applications, Systems and Equipment) or equivalent. Select cooling equipment capable of meeting the sensible and latent load of the building that is not sized more than 115% of total load or next available size. Select heating equipment of the lowest capacity required to meet the design heating load and provide the air movement required by any air conditioning equipment installed. Select system that is ENERGY STAR® certified or equivalent. Select outdoor units that are corrosion-protected for marine climate zonesDemolish existing HVAC units. Procure and install new like-for-like high efficiency Heat Pump units (SEER 15). If on the roof, reuse existing curbs on the roof, provide curb adapter if necessary. Install new disconnect switch and conduit to the new units in accordance with NFPA 70. Locate unit to provide clearance on all sides and top according to manufacturer specifications and service access according to applicable code. Situate outdoor unit on a non-wicking equipment pad. Install exterior ductwork using rigid, corrosion-resistant metal insulated to a minimum of R-12. Test and balance all modified systems. Perform duct leak remediation as required per SMACNA standards. Install smoke detector if required by local State Code. Connect new HVAC equipment to new Thermostat. Commision equipment and controls. Install smoke detectors inside the supply duct plenum of systems that move more than 2,500 cubic feet per minute (CFM) in accordance with the applicable building code
- **Improve Attic Insulation Levels:** The objective is to install batt insulation in the attic space. Ensure space can be safely insulated. Verify that installation area is intact, able to support insulation weight, and air sealed. Remove any existing insulation or vapor barrier materials from the installation area that are installed improperly. Select insulation materials that have a flame spread and smoke development index of 25/450 or less when tested in accordance with [ASTM E84](#) or [UL 723](#). Install batt insulation to prescribed R-value in every joist bay in full contact with the air barrier and all sides of the cavity without gaps, voids, compressions, or misalignments, if batt contains a facing material install it in contact with the conditioned space.
- **Install Fixed Tilt Solar Photovoltaic System:** The objective is to properly install a photovoltaic system. Verify current electrical panel and service line infrastructure is in good condition, compliant with codes, and of sufficient electrical capacity (Amps) to accommodate interconnection of solar power. Verify position of spare (unused) breaker or space to install new breaker in panel for solar power interconnection. If a roof installation is planned, verify that the roof will support the installation (e.g., dead load, wind load) and that the current roof covering is less than 5 years old. Verify that the type of roof is suitable for solar installation (e.g. not slate or wood shingle). The roof understructure shall be inspected and evaluated for support of PV system. Any reinforcements, such as blocking between rafters, shall be completed before load of PV system is applied. If a roof installation is planned, the roof shall be inspected, cleaned and any necessary repairs shall be made. Design the size of PV system to serve the prescribed load. Prepare electrical one line drawing. Prepare layout drawings showing location and connections of

all equipment. Provide list (make, model) of all equipment. Design PV system layout to provide safe access around PV modules as required by codes and standards, and required clearances around balance-of-system components such as inverter and switchgear. Locate PV Modules to minimize shading factor and maximize solar gain, but not interfere with existing systems or appliance operation (e.g., chimneys, vents, exhaust terminations). Secure approval of design by utility and secure interconnection agreement to operate utility-connected PV system. Secure electrical permit to install and operate PV system from Authority Having Jurisdiction (AHJ) (e.g. County building Dept.). Installer shall meet the requirements of AHJ. Secure the mounting structures to the roof following manufacturer instructions. Install flashing to make all roof penetrations weather-tight and leak-proof using instructions and materials specified by manufacturer. Install inverters and disconnects in a safe and accessible location, inverter shall be located in the shade when specified by manufacturer's instructions. Install solar panels on the mounting structures according to the manufacturer's instructions. The installation shall comply with all applicable codes and standards adopted by Authority Having Jurisdiction, including but not limited to: National Electric Code (NEC), International Residential Code (IRC), IEEE 1547 Standard for Interconnecting Distributed Resources with Electric Power Systems, UL 1703 Standard for Flat-Plate Photovoltaic Modules and Panels, Manufacturer's installation and operation manuals. Install all electrical components according to the NEC and authority having jurisdiction. Fasten wires with wire ties and conduit as per design and installation instructions. The system shall be connected to the electrical grid at a location and in a method approved by the utility. Monitor the system energy delivery for a minimum of 12 months and compare results with predicted energy production. Provide documentation to the building owner, including: copy of the installation and operation manual, electrical diagrams and schematics, certificate of inspection and approval, system performance benchmark data. Perform electrical tests to verify proper operation and system performance. Tests include open circuit voltage, operating current, resistance of grounding system (should be <25 ohms), and resistance of electrical insulation (should be >1 Megohm). Measured voltage shall be compared to reference voltage corrected for temperature. Measured current shall be compared to reference current corrected for insolation (sunlight level). The PV modules and inverter shall be warranted by the manufacturer. Provide occupants/owners with user's manual, warranty information, installation instructions, and installer contact information. Whole system shall be warranted by the installer for a period of at least 1 year. The warranty shall cover defects in materials and workmanship.

- **Replace Water Heater:** The objective is to select a water heater system that is efficient, durable and properly sized. Select a water heater that: has an Energy Factor (EF) of 0.93 or better fits in the installation space with required clearances and provides sufficient hot water for the home and occupants. Ensure that old equipment is permanently removed from service, in accordance with federal and local laws and regulations. Install water heater in compliance with applicable code (e.g., NFPA 70, IRC, IBC, IMC) and manufacturer specifications. Provide a level working space not less than 30" in length and 30" in width in front of the control side of the appliance. Install appliance and plumbing to allow for inspection, maintenance, and replacement of the appliance and its components, without disturbing other installed equipment, controls, piping, and components, other than what requires repair/replacement. Ensure that anode rod is accessible for replacement. If appliance is installed in or above conditioned space or in a location where water damage could occur, install a drain pan according to local plumbing code. Drain pan to the exterior of the building. Install a separate water cut-off valve for both the hot and cold water lines. Set discharge temperature to not exceed 120 degrees or as prescribed by local code.
- **Replace Thermostat / Reduce Hours of Operation:** The objective is to replace thermostat by a 24 hour fully programmable unit. Verify that sufficient number of thermostat wires is available to meet the needs of

the replacement unit and the existing system. Select a double-setback programmable thermostat that allows for full functionality of the installed system (supplementary heat, emergency heat, fan only, ventilation control, etc.). Install thermostat where it accurately reflects the temperature and humidity of the zone which it controls (i.e., not exposed to extreme temperatures, radiant heat sources, warm/cold walls, or drafts). Connect supplementary heat to second-stage heating terminal in accordance with manufacturer specifications. Install and connect outdoor temperature sensor that is compatible with the thermostat in accordance with manufacturer specifications. Calculate and select an optimum thermal balance point for supplementary heat operation in accordance with ANSI/ACCA Manual S and manufacturer specifications. Program the thermostat to match the equipment and control board settings per manufacturer specifications. Set time delay for fan start in accordance with manufacturer specifications and as appropriate for the climate zone (e.g., no time delay for hot humid climates, longer time delay for cold climates). Program the thermostat setbacks to a schedule that accommodates the occupant and reduces overall run time.

5. Recommended Operations and Maintenance Plan

The quality of the maintenance and the operation of the facility's energy systems have a direct effect on its overall energy efficiency. Energy-efficiency needs to be a consideration when implementing facility modifications, equipment replacements, and general corrective actions. The following is a list of activities that should be performed as part of the routine maintenance program for the property.

Building Envelope

- ✓ Ensure that the building envelope has proper caulking and weather stripping.
- ✓ Patch holes in the building envelope with foam insulation and fire rated caulk around combustion vents
- ✓ Inspect building vents semiannually for bird infestation
- ✓ Inspect windows monthly for damaged panes and failed thermal seals
- ✓ Repair and adjust automatic door closing mechanisms as needed.

Heating and Cooling

- ✗ Pilots lights on furnaces and boilers be turned off in summer
- ✗ All preventive maintenance should be performed on all furnaces and boilers, which would include cleaning of burners and heat exchanger tubes.
- ✗ Ensure that the combustion vents exhaust outside the conditioned space and the vent dampers are functional
- ✗ Ensure that the control valves are functioning properly before start of every season
- ✗ Ensure steam traps are functional before start of each heating season
- ✗ Ensure use of chemical treatment for boiler make up water
- ✗ Ensure boiler outside temperature re-set is set to 55F
- ✓ Ensure use of chemical treatment for Colling tower water to prevent corrosion
- ✓ Ensure the duct work in unconditioned space is un-compromised and well insulated
- ✗ Duct cleaning is recommended every 10 years. This should include sealing of ducts using products similar to 'aero-seal'
- ✗ Ensure use of economizer mode is functional and used
- ✓ Ensure that the outside air dampers actuators are operating correctly
- ✓ Ensure air coils in the AHU and FCA's are pressure washed annually
- ✓ Return vents should remain un-obstructed and be located centrally
- ✓ Temperature settings reduced in unoccupied areas and set points seasonally adjusted.
- ✗ Evaporator coils and condenser coils should be regularly cleaned to improve heat transfer
- ✗ Refrigerant pipes should be insulated with a minimum of ¾" thick Elastomeric Rubber Pipe Insulation
- ✗ Ensure refrigerant pressure is maintained in the condensers

Central Domestic Hot Water Heater

- ✗ Never place gas fired water heaters adjacent to return vents so as to prevent flame roll outs
- ✗ Ensure the circulation system is on timer to reduce the losses through re-circulation
- ✗ Ensure all hot water pipes are insulated with fiberglass insulation at all times
- ✗ Tank-type water heaters flushed monthly

Lighting Improvements

- ✓ Utilize bi-level lighting controls in stairwells and hallways.

- ✓ Use LED replacement lamps
- ✓ Clean lighting fixture reflective surfaces and translucent covers.
- ✓ Ensure that timers and/or photocells are operating correctly on exterior lighting
- ✓ Use occupancy sensors for offices and other rooms with infrequent occupancy

Existing Equipment and Replacements

- ✓ Ensure that refrigerator and freezer doors close and seal correctly
- ✓ Ensure kitchen and bathroom exhaust outside the building and the internal damper operates properly
- ✓ Ensure that bathroom vents exhaust out
- ✓ Office/computer equipment either in the “sleep” or “off” mode when not used

Key

x	Maintenance Measure is Not Applicable For the Given Facility
✓	Maintenance Measure is Applicable For the Given Facility



6. Appendices

- APPENDIX A: Photographic Record
- APPENDIX B: Site and Floor Plans
- APPENDIX C: Mechanical Inventory
- APPENDIX D: Energy Conservation Measures Calculations
- APPENDIX E: Other Supporting Documents



Appendix A: Photographic Record



Photographic Overview



1 - FRONT ELEVATION



2 - LEFT ELEVATION



3 - REAR ELEVATION



4 - RIGHT ELEVATION



5 - ROOF



6 - BASEMENT WALL INSULATION



Photographic Overview



7 - GYM



8 - LIBRARY



9 - BANK



10 - EXTERIOR WINDOWS



11 - EXTERIOR WINDOWS



12 - EXTERIOR WINDOW



Photographic Overview



13 - EXTERIOR WINDOWS



14 - EXTERIOR DOOR



15 - EXTERIOR DOOR



16 - DOMESTIC WATER HEATER



17 - FUEL OIL TANKS



18 - BOILERS

Photographic Overview



19 - HYDRONIC SPACE HEATER




20 - HYDRONIC BASEBOARD HEATER



21 - DUCTLESS MINI-SPLIT SYSTEM



22 - DUCTLESS MINI-SPLIT SYSTEM



23 - PASSENGER LIFT



24 - MAIN ELECTRICAL PANEL



Appendix B:

Site and Floor Plans



Site Plan



	Project Number	Project Name
	161246.23R000-005.267	Town Hall
	Source	On-Site Date
	Google	September 28, 2023



Appendix C: Mechanical Equipment Inventory



Mechanical Equipment Inventory

Equipment	Manufacturer	Model/ Type	Serial	Capacity	QTY
Boiler	Frontier	Boiler room	F21509152648	Oil, HVAC, 201 to 300 MBH	1
Boiler	Frontier	Boiler room	F21509152657	Oil, HVAC, 201 to 300 MBH	1
Unit Heater	Modine Manufacturing	Gym	05011086	Hydronic, 13 to 36 MBH	1
Unit Heater	Modine Manufacturing	Gym	05100786	Hydronic, 13 to 36 MBH	1
Unit Heater	Modine Manufacturing	Gym	05011086	Hydronic, 13 to 36 MBH	1
Unit Heater	Modine Manufacturing	Boys locker room	05191186	Hydronic, 13 to 36 MBH	1
Unit Heater	Modine Manufacturing	Gym	39010605-1384-	Hydronic, 13 to 36 MBH	1
Split System Ductless	Fujitsu	Building exterior	FXN 0 30 944	Single Zone, 2.5 to 3 TON	1
Split System Ductless	Fujitsu	Bank	KSA158697	Multi Zone, per 1 to 2 TON FCU	1
Split System Ductless	Fujitsu	Bank	MXA281960	Multi Zone, per 1 to 2 TON FCU	1
Split System Ductless	Fujitsu	Building exterior	FSN010726	Single Zone, 2.5 to 3 TON	1
Split System Ductless	Fujitsu	Bank	MXA 2 81 855	Multi Zone, per 1 to 2 TON FCU	1

Appendix D: Energy Conservation Measures Calculations

UIC	Improve Attic Insulation Levels	
EAE3	Location:	
Attributes:	Improve existing attic insulation from R-10 to R-49 by adding Batt Insulation	
ENTER EXISTING CONDITION		
ASHRAE Climatic Zone	<input type="text" value="Zone-6"/>	ASHRAE 90.1 Attic- Insulation Requirement: <input type="text" value="R-49"/>
Enter Total Surface Area Under Consideration:	<input type="text" value="10,000"/> Sq.Ft	Existing Net Effective R-Value: (Sq.Ft deg F/btu) <input type="text" value="10"/>
Proposed Type of Insulation To Be Added:	<input type="text" value="Batt Insulation"/> (Select)	Proposed Insulation Recommendation: <input type="text" value="Full Upgrade"/> (Select)
Recommended Level of Insulation To Be Added:	<input type="text" value="R-49"/>	Proposed Net Effective R-Value: (Sq.Ft deg F/btu) <input type="text" value="49"/> <small>(Post Retrofit-Final Net Insulation)</small>
ENTER CLIMATIC & SYSTEM DATA		
Annual Cooling Degree Days (CDD):	<input type="text" value="445"/>	Estimated Annual Cooling Plant Efficiency (EER): <input type="text" value="9.00"/> EER
Annual Heating Degree Days (HDD):	<input type="text" value="7,187"/>	Estimated Annual Heating Plant Efficiency: % <input type="text" value="72.00"/> %
WINTER		SUMMER
Select Type of Heating Fuel	<input type="text" value="No. 2 Oil"/> (Select)	Is the Property Cooled ? <input type="text" value="No"/> (Select)
Annual Conduction Losses From Existing Insulation	<input type="text" value="172,495"/> kBtu	Annual Conduction Losses From Existing Insulation <input type="text" value="10,680"/> kBtu
Annual Conduction Losses From Proposed Insulation	<input type="text" value="35,203"/> kBtu	Annual Conduction Losses From Proposed Insulation <input type="text" value="2,180"/> kBtu
Savings In Conduction Losses After Adding Insulation	<input type="text" value="137,292"/> kBtu	Savings In Conduction Losses After Adding Insulation <input type="text" value="0"/> kBtu
Estimated Total Annual Input Heating Energy Savings	<input type="text" value="422"/> Gallons	Estimated Total Annual Input Cooling Energy Savings <input type="text" value="0"/> kWh
Cost of Heating Fuel/Unit:	<input type="text" value="\$2.78"/> \$/Gal	Cost of Electricity/Unit <input type="text" value="\$0.18"/> \$\$
Annual Heating Cost Savings	<input type="text" value="\$1,172"/> \$\$	Annual Cooling Cost Savings <input type="text" value="\$0"/> \$\$
COST ANALYSIS		
Estimated O&M Savings	<input type="text" value="\$12"/> \$\$	Estimated Cost To Add Insulation on <input type="text" value="\$15,500"/>
Total Estimated Annual Cost Savings	<input type="text" value="\$1,184"/> \$\$	Estimated Total Installation Cost <input type="text" value="\$22,914"/> \$\$
Simple Pay Back Period	<input type="text" value="19.35"/> Years	<i>Type of Recommendation</i> <input type="text" value="Capital Cost ECM Recommendation"/>

Disclaimer: PREPARED BY BUREAU VERITAS (BV). FEBRUARY 2024 INFORMATION CONTAINED IN THIS DOCUMENT IS PRIVILEGED AND CONFIDENTIAL "TRADE SECRET" AND IS THE SOLE PROPERTY OF BV. THIS MATERIAL MUST BE CONSIDERED PRIVILEGED AND CONFIDENTIAL BY ALL PARTIES PRIVY.

ECM DESCRIPTION:
 The amount of heat conduction through ceiling and roof is proportional to its overall heat transfer coefficient (commonly called the U-factor) and the temperature difference between the conditioned space and its surrounding, modified by the effect of solar intensity and wind velocity on the exterior surfaces. One of the most effective ways to reduce heat transfer through ceilings and roofs is to retard heat conduction by adding insulation.
 Where the existing roof is sound and directly accessible from an attic or ceiling void, polyurethane foam or mineral fiber may be sprayed on the underside, with rigid batt or other applicable insulation for the inside surface. Insulation, typically fiber-glass batt, may also be laid on the top of a ceiling, taking care not to cover up light fixtures.
 Unimembers can degrade the performance of the insulation up to 20%, and resultant condensation can cause insulated structural the structure to deteriorate. Therefore, care should be taken to properly insulate the structural members. Often more energy can be conserved by insulating the ceiling rather than the roof unless the attic is being used for special storage, frequent access is required, or a moderate attic temperature is desired. However, if only the ceiling is insulated, any ducting or piping should be insulated to avoid excessive heat transfer or freezing. It is important to be sure that the attic is ventilated by providing one to two inches of ventilation area per square foot of attic.

Summary:
 Initial Investment: \$22,914 Simple Payback Period: 19.35 Yrs
 Annual Energy Cost Savings: \$1,184

UIC	Reduce HVAC Hours of Operation		
EAC3	Location: Throughout BLDG Air Handlers		
Attributes:	Self Learning Smart Thermostat - (4x) Sensors		
No. of Sensors Affected : 4 Qty.			
Select Type of Recommendation: Self Learning Smart Thermostat <small>(Select)</small> <small>(Selection Based on Type of Property)</small>			
Heating Load Calculation		Cooling Load Calculation	
Select Type of Heating Fuel	No. 2 Oil <small>(Select)</small>	Select Type of Cooling Fuel	Electric <small>(Default)</small>
Estimated Current Annual Energy Consumption For Winter Heating	1,438 Gallons	Estimated Current Annual Energy Consumption For Summer Cooling	40,568 kWh
	Weekdays Weekends		Weekdays Weekends
Day Time Set Back Hours	8.00 24.00	Day Time Set Back Hours	8.00 24.00
Night Time Set Back Hours	16.00	Night Time Set Back Hours	16.00
Hours Without Set Back	0.00 0.00	Hours Without Set Back	0.00 0.00
Typical Indoor Temp	72.00 °F	Typical Indoor Temp	72.00 °F
Temp Set Point With Set Back During Day Time	70.00 °F	Temp Set Point With Set Back During Day Time	74.00 °F
Temp Set Point With Set Back During Night Time	65.00 °F	Temp Set Point With Set Back During Night Time	76.00 °F
Average Heating Set Point	67.62 °F	Average Cooling Set Point	74.95 °F
Savings Per Degree Set Back For Heating Season <small>(Industry Standard, 2004)</small>	3%	Savings Per Degree Set Back For Cooling Season <small>(Industry Standard, 2004)</small>	6%
Estimated Annual Heating Energy Consumption	199,174 kBTu	Estimated Annual Cooling Energy Consumption	138,418 kBTu
Estimated New Annual Heating Energy Consumption	172,997 kBTu	Estimated New Annual Cooling Energy Consumption	113,898 kBTu
Estimated Annual Heating Energy Savings	189 Gallons	Estimated Annual Cooling Energy Savings	7,186 kWh
Cost Analysis			
Average Annual Cost of Heating Fuel:	\$2.78 /Gal	Estimated Investment Per Sensor: <small>(Includes Material, Labor & Installation Costs)</small>	\$207 \$\$
Average Annual Cost of Electricity:	\$0.18 /kWh	Total Estimated Cost For All Sensors:	\$1,224 \$\$
Estimated Annual Heating Cost Savings:	\$525 \$\$	Total Estimated Cost Savings From All Sensors:	\$1,819
Estimated Annual Cooling Cost Savings:	\$1,294 \$\$	Estimated Simple Pay Back Period	0.67 Yrs
<i>Type of Recommendation</i>		Capital Cost ECM Recommendation	

Disclaimer: PREPARED BY BUREAU VERITAS (BV). FEBRUARY 2024 INFORMATION CONTAINED IN THIS DOCUMENT IS PRIVILEGED AND CONFIDENTIAL "TRADE SECRET" AND IS THE SOLE PROPERTY OF BV. THIS MATERIAL MUST BE CONSIDERED PRIVILEGED AND CONFIDENTIAL BY ALL PARTIES PRIVY.

ECM DESCRIPTION:

Turning off energy-consuming systems when they are not needed is the most basic energy conservation technique. When a building is occupied intermittently, energy savings can be realized by minimizing the time the heating or cooling system is operated when the building is closed. Building control algorithms should be implemented to delay startup until the last moment and to shut down as early as possible. Because of the thermal inertia of both the building structure and its heating and cooling equipment, preheat or precool time is almost always required to raise or lower the space temperature to the desired level before the occupants return. This start-up time depends on the outdoor environment, the thermal response of the building, and the thermal performance of the space conditioning equipment. Similarly, the thermal inertia of the building maintains the indoor temperature at a comfortable level for a short period of time after the equipment is shut off. It allows the system to be turned off before the end of an occupied period. An optimum start/stop control accounts for these factors.

SUMMARY

Initial Investment:	\$1,224	Simple Payback Period:	0.67 Yrs
Annual Energy Cost Saving:	\$1,819		

UIC	Install Fixed Tilt Solar Photovoltaic System
EAR1	Location:
Attributes:	Install fixed tilt 71.6kW Solar Photovoltaic System consisting of 71.6kW Rooftop Fixed Array PV System;

Select State: **Vermont** **Electric Rate:** **\$0.18** \$/KWH **Annual Electric Consumption:** **336,703** KWh

Roof No.	Description	Location of the Array	DC System Size Per Roof	Estimated Battery Size	PV System Sizing For All Roofs	Estimated Number of 400 Watt PV Panels:	Total Estimated Annual Electricity Generated/ Roof	Total Estimated Electricity Generated (All Roofs)	Total Cost Savings	Installation Cost:	Simple Pay Back Period without Incentives	One Time Potential Utility or State Incentives	One Time Potential Federal Incentives	Annual Potential Incentives and Rebates		Simple Pay Back Period with All Incentives
			kW	KW-H	kW		kWh	kWh			Yrs		Federal Tax Credit	Federal REPI Incentive	Solar Renewable Certificates (SRECS)- (\$/MWH)	Years
1	Rooftop Fixed Array	Main Bldg	72	77	72	179	82,889	82,889	\$14,920	\$253,875	17.0	\$0	26%	\$0.00	Varies by State	17.0
2					0	0	0	0	\$0	\$0		\$0	\$0	\$0	\$0	
3					0	0	0	0	\$0	\$0		\$0	\$0	\$0	\$0	
4					0	0	0	0	\$0	\$0		\$0	\$0	\$0	\$0	
5					0	0	0	0	\$0	\$0		\$0	\$0	\$0	\$0	
6					0	0	0	0	\$0	\$0		\$0	\$0	\$0	\$0	
7					0	0	0	0	\$0	\$0		\$0	\$0	\$0	\$0	
8					0	0	0	0	\$0	\$0		\$0	\$0	\$0	\$0	
9					0	0	0	0	\$0	\$0		\$0	\$0	\$0	\$0	
10					0	0	0	0	\$0	\$0		\$0	\$0	\$0	\$0	
		0			72	179	82,889.0	82,889	\$14,920	\$253,875	17.02	\$0	\$0	\$0	\$0	17.02

Solar Rooftop Photovoltaic Analysis	
Total Number of Roofs	0
Estimated Number of Panels	179
Estimated KW Rating	72 kW
Potential Annual KWh Produced	82,889 kWh
% of Current Electricity Load	24.6%

Financial Analysis	
Investment Cost	\$253,875
Estimated Energy Cost Savings	\$14,920
Potential Rebates	\$0
Potential Annual Incentives	\$0
Payback without Incentives	17.0 years
Incentive Payback but without SRECS	17.0 years
Payback with All Incentives	17.0 years

UIC		Replace Existing Water Heater With New Energy Efficient Units			
EAD3	Location:				
Attributes:	Replace 1x 119kBtus No. 2 Oil water heaters with 80-Gal,4.5-kW 3.45EF Heat Pump water heater				
Step 1	Existing Water Heater Details	<i>Specify Location Here</i>	<i>Specify Location Here</i>	<i>Specify Location Here</i>	<i>Specify Location Here</i>
	Number of Water Heaters Being Replaced:	1			
	Select Existing Hot Water Heater Fuel	No. 2 Oil	Electric	Natural Gas	Natural Gas
	Insert Energy Factor of Existing Water Heater	0.53 EF			
	Input Existing Water Heater Input Rating	119.00 kBtus			4.50 kBtus
	Select One Method For Calculation	Annual Heating Hours	Annual Heating Hours	Annual DWH Load	Annual DWH Load
	Insert Average Annual Hours of Operation	780 hrs			
	Annual Water Heater Energy Consumption/Heater	670 Gallons	0 kWh	#DIV/0! hrs	0 hrs
	Total Estimated Annual Energy Consumption For all Heaters	663 Gallons	0 kWh	0 Therms	0 Therms
	Total Estimated Annual Operating Energy Costs For all Heaters	\$1,843 \$	\$0 \$	\$0 \$	\$0 \$
Step 2	Proposed New Water Heater				
	Proposed Quantity of Water Heaters:	3			
	Proposed Hot Water Heater Fuel	Heat Pump			
	Capacity of the Proposed New Water Heater	80-Gal,4.5-kW			
	Energy Factor of Proposed Water Heater	3.45 EF	0.00 EF	0.00 EF	0.00 EF
	Proposed Water Heater Input Rating	15.35 kW	0.00 kW	0.00 kW	0.00 kW
	Annual kBtuh Consumption For All The Proposed Water Heaters	14,259 kBtuh	0 kBtuh	0 kBtuh	0 kBtuh
	Estimated Annual Water Heater Fuel Consumption (All Heaters)	4,179 kWh	0 kWh	0 kWh	0 kWh
	Estimated Total Annual Energy Costs	\$752	\$0	\$0	\$0
Step 3	Energy & Cost Saving Calculation				
	Estimated Material Cost of New Water Heater	\$6,420	\$0	\$0	\$0
	Estimated Labor Cost of New Water Heater	\$1,605	\$0	\$0	\$0
	Total Estimated Installation Cost	\$8,025	\$0	\$0	\$0
	Total Estimated Annual Cost Savings	\$1,091	\$0		\$0
	Total Annual Cost Savings:	\$1,091	Total Initial Investment::	\$8,025	
	Simple Pay Back Period	7.36			
	<i>Type of Recommendation</i>	Capital Cost ECM Recommendation			

UIC		Replace HVAC Units With Electric /Heat Pump HVAC Units			
EAH-15	Location:				
Attributes:	Replace (2x) 170MBH - 9 Ton RTU With (2x) 40 Tons - Electric Heat RTU System;				
		<i>Specify Location</i>	<i>Specify Location</i>	<i>Specify Location</i>	<i>Specify Location</i>
Heating System					
Number of Heating Systems to be replaced	<input type="text" value="2"/> Qty	<input type="text"/> Qty	<input type="text"/> Qty	<input type="text"/> Qty	<input type="text"/> Qty
Heating Fuel:	<input type="text" value="No. 2 Oil"/>	<input type="text"/>	<input type="text" value="Natural Gas"/>	<input type="text" value="Natural Gas"/>	<input type="text"/>
Heating System Capacity (Each)	<input type="text" value="170"/> MBH	<input type="text"/> MBH	<input type="text"/> MBH	<input type="text"/> MBH	<input type="text"/> MBH
De-rated AFUE rating For Each Heating System	<input type="text" value="72.00"/> %	<input type="text"/> %	<input type="text"/> %	<input type="text"/> %	<input type="text"/> %
Estimated Annual Operating Hours:	<input type="text" value="2,080"/> Hrs	<input type="text"/> Hrs	<input type="text"/> Hrs	<input type="text"/> Hrs	<input type="text"/> Hrs
Estimated Annual Energy Use from All Heating Systems	<input type="text" value="1,438"/> Gallons	<input type="text" value="0"/> #N/A	<input type="text" value="0"/> Therms	<input type="text" value="0"/> Therms	<input type="text"/> Therms
Cooling					
Unit has Cooling?	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="Yes"/>	<input type="text" value="Yes"/>	<input type="text"/>
Refrigerant in Cooling System	<input type="text" value="R-410A"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>
Cooling Capacity for Each Unit	<input type="text" value="108,000"/> Btuh	<input type="text"/> Btuh	<input type="text"/> Btuh	<input type="text"/> Btuh	<input type="text"/> Btuh
EER of the Existing Cooling System:	<input type="text" value="9.00"/> EER	<input type="text"/> EER	<input type="text"/> EER	<input type="text"/> EER	<input type="text"/> EER
Estimated Annual Operating Hours:	<input type="text" value="448"/> Hrs	<input type="text"/> Hrs	<input type="text"/> Hrs	<input type="text"/> Hrs	<input type="text"/> Hrs
Energy Consumption From All Existing Air conditioner:	<input type="text" value="10,752"/> kWh	<input type="text" value="0"/> kWh	<input type="text" value="0"/> kWh	<input type="text" value="0"/> kWh	<input type="text"/> kWh
Proposed System					
Proposed System:	<input type="text" value="40 Tons - Electric Heat RTU"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>
Proposed Cooling System Capacity	<input type="text" value="480,000"/> Btuh	<input type="text" value="0"/> Btuh	<input type="text" value="0"/> Btuh	<input type="text" value="0"/> Btuh	<input type="text" value="0"/> Btuh
EER of Proposed Air-Conditioning System:	<input type="text" value="15.00"/> EER	<input type="text" value="0.00"/> EER	<input type="text" value="0.00"/> EER	<input type="text" value="0.00"/> EER	<input type="text" value="0.00"/> EER
Total Energy Consumption For Proposed RTU - Cooling:	<input type="text" value="17,678"/> kWh	<input type="text" value="0"/> kWh	<input type="text" value="0"/> kWh	<input type="text" value="0"/> kWh	<input type="text" value="0"/> kWh
Proposed Heating System Input:	<input type="text" value="35.87"/> kW	<input type="text" value="0.00"/> kW	<input type="text" value="0.00"/> kW	<input type="text" value="0.00"/> kW	<input type="text" value="0.00"/> kW
COP of Proposed RTU Heating System:	<input type="text" value="1.00"/> COP	<input type="text" value="0.00"/> COP	<input type="text" value="0.00"/> COP	<input type="text" value="0.00"/> COP	<input type="text" value="0.00"/> COP
Total Energy Consumption For Proposed RTU Heat:	<input type="text" value="74,617"/> kWh	<input type="text" value="0"/> kWh	<input type="text" value="0"/> kWh	<input type="text" value="0"/> kWh	<input type="text" value="0"/> kWh
Estimated Annual Energy Consumption From All Systems:	<input type="text" value="40,568"/> kWh	<input type="text" value="0"/> kWh	<input type="text" value="0"/> kWh	<input type="text" value="0"/> kWh	<input type="text" value="0"/> kWh
Savings Analysis					
Annual Energy Savings From Heating Systems:	<input type="text" value="-55,418"/> kBtuh	<input type="text" value="0"/> kBtuh	<input type="text" value="0"/> kBtuh	<input type="text" value="0"/> kBtuh	<input type="text" value="0"/> kBtuh
Annual kWh savings for all Air conditioner:	<input type="text" value="-6,926"/> kWh	<input type="text" value="0"/> kWh	<input type="text" value="0"/> kWh	<input type="text" value="0"/> kWh	<input type="text" value="0"/> kWh
Material Cost For All RTU(s):	<input type="text" value="\$80,000"/>	<input type="text" value="\$0"/>	<input type="text" value="\$0"/>	<input type="text" value="\$0"/>	<input type="text" value="\$0"/>
Labor Cost for All RTU(s):	<input type="text" value="\$24,000"/>	<input type="text" value="\$0"/>	<input type="text" value="\$0"/>	<input type="text" value="\$0"/>	<input type="text" value="\$0"/>
Installed Cost for all RTU(s):	<input type="text" value="\$104,000"/>	<input type="text" value="\$0"/>	<input type="text" value="\$0"/>	<input type="text" value="\$0"/>	<input type="text" value="\$0"/>
Total Investment	<input type="text" value="\$104,000"/>	<input type="text" value="\$0"/>	<input type="text" value="\$0"/>	<input type="text" value="\$0"/>	<input type="text" value="\$0"/>
Estimated Annual Energy Cost Savings:	<input type="text" value="-\$4,551"/>	<input type="text"/>	<input type="text" value="\$0"/>	<input type="text" value="\$0"/>	<input type="text"/>
Estimated Annual Energy Savings:	<input type="text" value="-79,051"/> kBtuh	<input type="text"/>	<input type="text" value="0"/> kBtuh	<input type="text" value="0"/> kBtuh	<input type="text" value="0"/> kBtuh
Total Utility Savings	<input type="text" value="0"/> Therms	<input type="text" value="0"/> Gal	<input type="text" value="1,438"/> Gal	<input type="text" value="-29,816"/> kWh	<input type="text"/>
Total Initial Investment:	<input type="text" value="\$104,000"/>	Total Annual Utility Cost Savings:		<input type="text" value="-\$4,551"/>	
Simple Payback:	<input type="text" value="-22.85"/> Yrs				
Type of Recommendation	<input type="text" value="Capital Cost ECM Recommendation"/>				

UIC		Control External Air Leakage In Commercial Buildings	
EAE4A		Location:	
Attributes:		Perform air sealing of building through Installing 120x linear feet of door sweeps	
ENTER EXISTING CONDITION			
Insert Existing Estimated Air Change Rate/Hr (ACH 1): <small>(Existing Air Changes Per Hour, 3 is very leaky and 0.35 ideal)</small>	<input type="text" value="0.75"/>	Cubic Feet/Min (CFM 1):	<input type="text" value="125"/>
Insert Proposed Estimated Air Change Rate/Hr (ACH 2):	<input type="text" value="0.35"/>	Cubic Feet/Min (CFM 2):	<input type="text" value="58"/>
Estimated Space Volume Under Consideration	<input type="text" value="10,000"/>	Cu.Ft	
WINTER		SUMMER	
Select Type of Heating Fuel	<input type="text" value="No. 2 Oil"/> (Select)	Is The Building Cooled?	<input type="text" value="No"/>
Estimated Annual Heating Plant Efficiency	<input type="text" value="72.00"/> %	Estimated Annual Cooling Plant Efficiency	<input type="text" value="0.00"/> EER
Annual Heating Degree Days(HDD):	<input type="text" value="7,187"/>	Annual Cooling Degree Days(CDD):	<input type="text" value="445"/>
Estimated Total Annual Input Heating Energy Savings	<input type="text" value="216"/> Gallons	Estimated Total Annual Input Cooling Energy Savings	<input type="text" value="0"/> kWh
Cost/Unit of Heating Fuel:	<input type="text" value="\$2.78"/> \$/Gal	Cost/Unit For Electricity	<input type="text" value="\$0.18"/> \$\$
Estimated Annual Heating Cost Savings	<input type="text" value="\$600"/> \$\$	Estimated Annual Cooling Cost Savings	<input type="text" value="\$0"/> \$\$
Cost Analysis			
Install Flush Mounted, Vinyl Door Sweeps ?	<input type="text" value="Yes"/>	Total Length of Door Sweeps to Be Installed: <small>(3.5' Standard Width Door)</small>	<input type="text" value="120"/> LF
Install Window Air Conditioner Covers For Winter:	<input type="text" value="No"/>	Number of Air Conditioner Covers To Be Installed: <small>(Covers would meet HUD Chapter-12 Energy Conservation Compliance Section 329C)</small>	<input type="text" value=""/>
Estimated Annual O&M Savings	<input type="text" value="\$30"/>	Estimated Length of Joints To Be Re-Caulked: <small>(Includes Demolition and Re-Caulking)</small>	<input type="text" value=""/>
Total Estimated Annual Cost Savings	<input type="text" value="\$630"/>	Total Cost For Controlling Air Leakage	<input type="text" value="\$2,168"/>
Simple Pay Back Period	<input type="text" value="3.44"/> Yrs	Type of Recommendation	<input type="text" value="Capital Cost ECM Recommendation"/>

Disclaimer: PREPARED BY BUREAU VERITAS (BV). FEBRUARY 2024 INFORMATION CONTAINED IN THIS DOCUMENT IS PRIVILEGED AND CONFIDENTIAL "TRADE SECRET" AND IS THE SOLE PROPERTY OF BV. THIS MATERIAL MUST BE CONSIDERED PRIVILEGED AND CONFIDENTIAL BY ALL PARTIES PRIVY.

ECM DESCRIPTION:

One of the most commonly used methods for reducing air leakage through building structures is caulking and weather stripping.

Particularly effective measures include caulking cracks around windows and door frames and weather stripping around windows and doors. Weather-stripping and caulking of doors and windows, helps in thermally isolating of the building with the outside atmosphere. This prevents the infiltration of external un-conditioned air along with moisture and humidity into the conditioned space at the same time, prevents the conditioned air from escaping out. A precisely thermally isolated building directly affects the cooling and heating load on the facilities HVAC system as it has to put in less effort in maintaining the desired temperature inside the facility. As per ASHRAE a well insulated and ventilated building should have an air change rate not more than 0.35 per hour. In order to ensure proper thermal isolation of the property, BV recommends ensuring that the weather-stripping and caulking of all external doors and windows remains intact. Its also recommended that door sweeps be installed under all the doors opening into conditioned space. Any visible cracks between the window frame and wall should be plugged by caulking.

In case of building with window airconditioners, BV recommends use of interior/exterior window airconditioner covers so as to prevent cold air drafts into the conditioned space during the winter so as to save on heating costs.

SUMMARY:

Initial Investment: \$2,168 Simple Pay Back Perio: 3.44 Yrs
Annual Energy Cost Savings: \$630

Appendix E:

Other Supporting Documents

Glossary of Terms and Acronyms - Energy Audits

ECM – Energy Conservation Measures are projects recommended to reduce energy consumption. These can be No/Low cost items implemented as part of routine maintenance or Capital Cost items to be implemented as a capital improvement project.

Initial Investment – The estimated cost of implementing an ECM project. Estimates typically are based on R.S. Means Construction cost data and Industry Standards.

Annual Energy Savings – The reduction in energy consumption attributable to the implementation of a particular ECM. These savings values do not include the interactive effects of other ECMs.

Cost Savings – The expected reduction in utility or energy costs achieved through the corresponding reduction in energy consumption by implementation of an ECM.

Simple Payback Period – The number of years required for the cumulative value of energy or water cost savings less future non-fuel or non-water costs to equal the investment costs of the building energy or water system, without consideration of discount rates.

EUL – Expected Useful Life is the estimated lifespan of a typical piece of equipment based on industry accepted standards.

RUL – Remaining Useful Life is the EUL minus the effective age of the equipment and reflects the estimated number of operating years remaining for the item.

SIR – The savings-to-investment ratio is the ratio of the present value savings to the present value costs of an energy or water conservation measure. The numerator of the ratio is the present value of net savings in energy or water and non-fuel or non-water operation and maintenance costs attributable to the proposed energy or water conservation measure. The denominator of the ratio is the present value of the net increase in investment and replacement costs less salvage value attributable to the proposed energy or water conservation measure. It is recommended that energy-efficiency recommendations be based on a calculated SIR, with larger SIRs receiving a higher priority. A project typically is recommended only if the SIR is greater than or equal to 1.0, unless other factors outweigh the financial benefit.

Life Cycle Cost – The sum of the present values of (a) Investment costs, less salvage values at the end of the study period; (b) Non-fuel operation and maintenance costs; (c) Replacement costs less salvage costs of replaced building systems; and (d) Energy and/or water costs.

Life Cycle Savings – The sum of the estimated annual cost savings over the EUL of the recommended ECM, expressed in present value dollars.

Building Site Energy Use Intensity – The sum of the total site energy use in thousands of Btu per unit of gross building area. Site energy accounts for all energy consumed at the building location only not the energy consumed during generation and transmission of the energy to the site.

Building Source Energy Use Intensity – The sum of the total source energy use in thousands of Btu per unit of gross building area. Source energy is the energy consumed during generation and transmission in supplying the energy to your site.

Building Cost Intensity – This metric is the sum of all energy use costs in dollars per unit of gross building area.

Greenhouse Gas Emissions – Although there are numerous gases that are classified as contributors to the total for Greenhouse Emissions, the scope of this energy audit focuses on carbon dioxide (CO₂). Carbon dioxide enters the atmosphere through the burning of fossil fuels (oil, natural gas, and coal), solid waste, trees and wood products, and also as a result of other chemical reactions (e.g., manufacture of cement).